


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id

KAESER 1693

Component Compressor

KAESER SIGMA (OEM) S-460 (3 GAL)

	O.				
Δ	G١	VИ			-
 $^{-}$	ωп	N	J	J	\sim

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0825684	WC0659336	WC0659352
Sample Date		Client Info		23 May 2024	01 Jun 2023	29 Jun 2022
Machine Age	hrs	Client Info		7770	4417	1440
Oil Age	hrs	Client Info		3363	0	114
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	11	2	1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	2
Barium	ppm	ASTM D5185m	90	7	34	46
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	26	64	90
Calcium	ppm	ASTM D5185m	2	0	2	4
Phosphorus	ppm	ASTM D5185m		0	<1	59
Zinc	ppm	ASTM D5185m		4	0	6
Sulfur	ppm	ASTM D5185m		18150	20920	25469
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	5	3
Sodium	ppm	ASTM D5185m		11	23	22
Potassium	ppm	ASTM D5185m	>20	5	5	10
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.37	0.29	0.33



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	45.2	44.7	44.3
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color						
Bottom						







Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: WC0825684 Lab Number : 06221380 Unique Number : 11099577

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 26 Jun 2024 Tested : 27 Jun 2024

Diagnosed : 27 Jun 2024 - Sean Felton

AMAZON 550 OAK RIDGE DR HAZELTON, PA US 18202

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: