


# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**SSI PR6600**  
Component  
**Hydraulic System**  
Fluid  
**VISH2-100-68 (--- GAL)**

**DIAGNOSIS**

**Recommendation**

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

**Contamination**

There is a high amount of particulates present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2	
Sample Number	Client Info	<b>Y2K0001641</b>	Y2K0001647	Y2K0001486	
Sample Date	Client Info	<b>05 Jul 2024</b>	08 Jun 2024	01 May 2024	
Machine Age	hrs	Client Info	<b>28100</b>	27820	0
Oil Age	hrs	Client Info	<b>2020</b>	1740	1317
Oil Changed	Client Info	<b>Changed</b>	Not Changd	Not Changd	
Sample Status		<b>ABNORMAL</b>	ATTENTION	NORMAL	

**WEAR METALS**

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185m	>20	<b>6</b>	6	<1
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	0
Silver	ppm	ASTM D5185m		<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m	>10	<b>0</b>	2	0
Lead	ppm	ASTM D5185m	>10	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>75	<b>0</b>	2	<1
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	<1	0

**ADDITIVES**

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>0</b>	1	6
Molybdenum	ppm	ASTM D5185m		<b>0</b>	3	0
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>7</b>	7	7
Calcium	ppm	ASTM D5185m		<b>43</b>	49	47
Phosphorus	ppm	ASTM D5185m		<b>911</b>	718	849
Zinc	ppm	ASTM D5185m		<b>1152</b>	1082	1111
Sulfur	ppm	ASTM D5185m		<b>3478</b>	2741	3355

**CONTAMINANTS**

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>20	<b>&lt;1</b>	2	<1
Sodium	ppm	ASTM D5185m		<b>3</b>	2	4
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	1	2
Water	%	ASTM D6304	>0.1	<b>0.003</b>	0.003	0.002
ppm Water	ppm	ASTM D6304	>1000	<b>39</b>	29	18

**FLUID CLEANLINESS**


method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	<b>▲ 3100</b>	● 3518	554
Particles >6µm	ASTM D7647	>640	<b>▲ 872</b>	● 677	97
Particles >14µm	ASTM D7647	>80	<b>▲ 167</b>	70	2
Particles >21µm	ASTM D7647	>20	<b>▲ 64</b>	20	0
Particles >38µm	ASTM D7647	>4	<b>▲ 6</b>	0	0
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>18/16/13	<b>▲ 19/17/15</b>	● 19/17/13	16/14/9

**FLUID DEGRADATION**


method	limit/base	current	history1	history2		
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.75</b>	0.88	0.78

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### Water (KF)




### Acid Number



### Water (KF)




### Viscosity @ 40°C








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>LIGHT</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>46.9</b>	45.1	46.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : Y2K0001641 **Received** : 11 Jul 2024  
**Lab Number** : **06233837** **Tested** : 12 Jul 2024  
**Unique Number** : 11122671 **Diagnosed** : 13 Jul 2024 - Don Baldrige  
**Test Package** : MOB 2 ( Additional Tests: KF )

**COOPER TANK**  
 123 VARICK AVE  
 BROOKLYN, NY  
 US 11237  
 Contact: RAY KVEDARAS  
 rkvedaras@coopertank.com  
 T: (718)384-7727  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)