


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 5620737

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012272	KCP29140	
Sample Date		Client Info		07 Jun 2024	02 Sep 2020	
Machine Age	hrs	Client Info		7134	3487	
Oil Age	hrs	Client Info		0	3487	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	<1	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	<u> </u>	8	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	2	
Barium	ppm	ASTM D5185m	90	0	<u> </u>	
Molybdenum	ppm	ASTM D5185m	0	0	<1	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	4	<u></u> 51	
Calcium	ppm	ASTM D5185m	0	0	<1	
Phosphorus	ppm	ASTM D5185m	0	<1	1	
Zinc	ppm	ASTM D5185m	0	4	<1	
Sulfur	ppm	ASTM D5185m	23500	17003	18706	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	6	3	
Sodium	ppm	ASTM D5185m		<1	9	
Potassium	ppm	ASTM D5185m	>20	0	2	
Water	%	ASTM D6304	>0.05	<u> </u>	△ 0.830	
ppm Water	ppm	ASTM D6304	>500	<u></u> 5590	▲ 8300	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	4.0	0.37	0.372	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: KCPA012272 Lab Number : 06233847 Unique Number : 11122681

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 11 Jul 2024 **Tested** : 13 Jul 2024

: 13 Jul 2024 - Don Baldridge Diagnosed

KING OF PRUSSIA, PA US 19406 Contact: Service Manager

ZIPS DRY CLEANERS

371 W DEKALB PIKE

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: ZIPKIN [WUSCAR] 06233847 (Generated: 07/13/2024 13:48:46) Rev: 1

T:

F: