

## **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 2954201**

### Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012691	KCPA011837	
Sample Date		Client Info		01 May 2024	30 Nov 2023	
Machine Age	hrs	Client Info		37330	35459	
Oil Age	hrs	Client Info		3000	0	
Oil Changed		Client Info		Not Changd	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead		ASTM D5185m	>10	0	0	
	ppm			-		
Copper Tin	ppm	ASTM D5185m	>50 >10	0	4	
	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	79	17	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	1	
Magnesium	ppm	ASTM D5185m	90	84	54	
Calcium	ppm	ASTM D5185m	2	2	0	
Phosphorus	ppm	ASTM D5185m		0	0	
Zinc	ppm	ASTM D5185m		6	0	
Sulfur	ppm	ASTM D5185m		23611	22088	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		21	14	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.013	0.003	
ppm Water	ppm	ASTM D6304	>500	134	35	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		16952	15555	
Particles >6µm		ASTM D7647	>1300	<u> </u>	<b>A</b> 3031	
Particles >14µm		ASTM D7647	>80	<b>A</b> 351	<b>9</b> 5	
Particles >21µm		ASTM D7647	>20	<u> </u>	19	
Particles >38µm		ASTM D7647	>4	3	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	21/19/14	
		. /				
		method	limit/base	current	history1	history2
FLUID DEGRADA Acid Number (AN)	TION mg KOH/g	method ASTM D8045	limit/base	current 0.37	history1 0.36	history2



(maa)

Water

Water (

48


(J-04 4 4 B

47

4(

38

Abno



method

\*Visual

\*Visual

\*Visual

limit/base

NONE

NONE

NONE

NONE

current

NONE

NONE

NONE

NONE

NONE

history1


NONE


NONE

NONE

NONE

history2







To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: KF, PrtCount)

50

40 ŝ

40

35

Laboratory

Sample No.

Lab Number

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate 12367

Contact/Location: Service Manager - OLDWESUT

T:

F:

Contact: Service Manager