




# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id

## KAESER 6434789

Component

### Compressor

Fluid

### KAESER SIGMA (OEM) M-460 (--- GAL)

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KCPA017445</b>	KCPA007663	KCP47975
Sample Date	Client Info			<b>08 Jul 2024</b>	10 Nov 2023	15 Nov 2022
Machine Age	hrs	Client Info		<b>34767</b>	29957	29954
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>Changed</b>	N/A	Changed
Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>0</b>	0	0
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>50	<b>0</b>	<1	21
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	90	<b>8</b>	83	2
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	100	<b>47</b>	86	4
Calcium	ppm	ASTM D5185m	0	<b>0</b>	2	12
Phosphorus	ppm	ASTM D5185m	0	<b>&lt;1</b>	3	7
Zinc	ppm	ASTM D5185m	0	<b>21</b>	0	10
Sulfur	ppm	ASTM D5185m	23500	<b>23547</b>	20917	20693

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>2</b>	<1	<1
Sodium	ppm	ASTM D5185m		<b>8</b>	<1	2
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	<1	0
Water	%	ASTM D6304	>0.05	<b>0.011</b>	0.021	0.018
ppm Water	ppm	ASTM D6304	>500	<b>114</b>	211	184.9

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>8662</b>	11553	77046
Particles >6µm		ASTM D7647	>1300	<b>▲ 3154</b>	▲ 3556	▲ 27787
Particles >14µm		ASTM D7647	>80	<b>▲ 197</b>	▲ 218	▲ 3342
Particles >21µm		ASTM D7647	>20	<b>▲ 30</b>	▲ 47	▲ 768
Particles >38µm		ASTM D7647	>4	<b>2</b>	2	▲ 36
Particles >71µm		ASTM D7647	>3	<b>0</b>	1	3
Oil Cleanliness		ISO 4406 (c)	>--/17/13	<b>▲ 20/19/15</b>	▲ 21/19/15	▲ 23/22/19

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.38</b>	0.37	0.44


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	46.5	45.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA017445 **Received** : 11 Jul 2024  
**Lab Number** : 06233858 **Tested** : 12 Jul 2024  
**Unique Number** : 11122692 **Diagnosed** : 13 Jul 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**UPS**  
 11800 S HARLAN RD  
 LATHROP, CA  
 US 95330  
 Contact: J. BILAL  
 jbilal@ups.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)