

OIL ANALYSIS REPORT

Machine Id

KAESER CSD 125 4491879 (S/N 1282)

Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA020838	KCPA012727	KCP53990
Sample Date		Client Info		27 Jun 2024	16 Apr 2024	23 May 2023
Machine Age	hrs	Client Info		37470	35923	29034
Oil Age	hrs	Client Info		2667	5003	0
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				ABNORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	<1	<1
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	2	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	15	8	9
Tin	ppm		>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	1	4	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	5	6	4
Calcium	ppm	ASTM D5185m	2	0	3	0
Phosphorus	ppm	ASTM D5185m		0	2	2
Zinc	ppm	ASTM D5185m		2	0	0
Sulfur	ppm	ASTM D5185m		18637	18325	14954
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		<1	0	1
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304		0.008	0.007	0.008
ppm Water	ppm	ASTM D6304		83	76	85.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		20870	9741	
Particles >6µm		ASTM D7647	>1300	<u> </u>	2308	
Particles >14µm		ASTM D7647	>80	<u> </u>	114	
Particles >21µm		ASTM D7647	>20	6	25	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 22/20/13	20/18/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.45	0.49	0.48


KAESER COMPRESSORS Built for a lifetime."


OIL ANALYSIS REPORT














Bottom



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: AXINEW [WUSCAR] 06233865 (Generated: 07/13/2024 13:59:11) Rev: 1

Certificate 12367

Contact/Location: P. LONGIA - AXINEW

plongia@axiumplastics.com

Page 2 of 2

T:

F: