


OIL ANALYSIS REPORT

Sample Rating Trend



Area
[TS01726877]
 Machine Id
112069 - HP2 (S/N LE12455)
 Component
Compressor
 Fluid
CIMARRON HB-150 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		TO90004470	TO90004005	---
Sample Date	Client Info		11 Jul 2024	02 May 2024	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	SEVERE	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	11	6	---
Chromium	ppm	ASTM D5185m >10	0	<1	---
Nickel	ppm	ASTM D5185m	<1	<1	---
Titanium	ppm	ASTM D5185m	0	<1	---
Silver	ppm	ASTM D5185m	0	0	---
Aluminum	ppm	ASTM D5185m >25	<1	2	---
Lead	ppm	ASTM D5185m >25	0	0	---
Copper	ppm	ASTM D5185m >50	0	<1	---
Tin	ppm	ASTM D5185m >15	1	<1	---
Vanadium	ppm	ASTM D5185m	0	<1	---
Cadmium	ppm	ASTM D5185m	0	<1	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<1	0	---
Barium	ppm	ASTM D5185m 0	0	1	---
Molybdenum	ppm	ASTM D5185m 0	0	<1	---
Manganese	ppm	ASTM D5185m	0	0	---
Magnesium	ppm	ASTM D5185m 0	0	<1	---
Calcium	ppm	ASTM D5185m 0	0	6	---
Phosphorus	ppm	ASTM D5185m 0	15	23	---
Zinc	ppm	ASTM D5185m 0	0	5	---
Sulfur	ppm	ASTM D5185m 0	521	189	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	1	---
Sodium	ppm	ASTM D5185m	1	8	---
Potassium	ppm	ASTM D5185m >20	3	2	---
Water	%	ASTM D6304 >2.26	0.677	▲ 2.10	---
ppm Water	ppm	ASTM D6304 >22600	6770	▲ 21000	---






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 194599	▲ 106811	---
Particles >6µm	ASTM D7647	>2500	▲ 66247	▲ 31607	---
Particles >14µm	ASTM D7647	>320	▲ 2109	● 617	---
Particles >21µm	ASTM D7647	>80	▲ 453	51	---
Particles >38µm	ASTM D7647	>20	▲ 21	0	---
Particles >71µm	ASTM D7647	>4	▲ 6	0	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 25/23/18	▲ 24/22/16	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.38	0.086	---


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>2.26	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	151	133	128
Visc @ 100°C	cSt	ASTM D445	28	24.7	24.0
Viscosity Index (VI)	Scale	ASTM D2270	224	220	220

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90004470 **Received** : 11 Jul 2024
Lab Number : 06233926 **Tested** : 16 Jul 2024
Unique Number : 11122760 **Diagnosed** : 16 Jul 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

CIMARRON ENERGY - CARLSBAD
 4425 GRANDI RD, UNIT F
 CARLSBAD, NM
 UM 88220-8923
 Contact: CARLOS LEAL
 cleal@cimarron.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)