

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area D-100 [SO-291564] 040326019 - PEASE PLASTIC

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0002188		
Sample Date		Client Info		20 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	10		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		217		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.29		



OIL ANALYSIS REPORT

VISUAL



	VISUAL		method	limit/base	current	nistory i	nistory2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Jun 20/24	Appearance	scalar	*Visual	NORML	NORML			
Junî	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPER		method	limit/base	current	history1	history2	
				IIIIII/Dase		TIIStOLA	TIIStOLYZ	
	Visc @ 40°C	cSt	ASTM D445		101			
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
						,		
+ 92/02nnL	Color					no image	no image	
	Bottom					no image	no image	
	Ferrous Alloys	ls		Jun20/24				
	→ Viscosity @ 40°C			7				
	120				Acid Number			
	100 - Abnormal 40 - Abnormal 20 - Ft2002 ump			Jun 20/24 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.	Jun20/24		Act of Carrier	
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report Denotes test methods that	: UFD0002188 : 06233936 : 11122770 : IND 2 , contact Customer Serv are outside of the ISO 1	Rece Teste Diagi vice at 1-8				FLUID-AIRE DYNAMIC 225 SPRING LAKE D ITASCA, US 6014 Contact: ED DIENE ed.diener@fluidairedynamics.co T: (847)678-838 1 106:2012)		

ŝ,

Contact/Location: ED DIENER - UCFLUSCH