


# **OIL ANALYSIS REPORT**

# PG46 [SO-291562] PNEUTECH AK100013680 - PEASE PLASTIC

Component Compressor





## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0002164	UFD0000096	
Sample Date		Client Info		20 Jun 2024	18 Oct 2023	
Machine Age	hrs	Client Info		6327	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m		<1	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	<1	0	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	0	0	
Tin	ppm	ASTM D5185m	>15	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	2	
Calcium	ppm	ASTM D5185m		0	2	
Phosphorus	ppm	ASTM D5185m		250	236	
Zinc	ppm	ASTM D5185m		89	82	
Sulfur	ppm	ASTM D5185m		90	132	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	2	
Sodium	ppm	ASTM D5185m		3	4	
Potassium	ppm	ASTM D5185m	>20	2	1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.24	0.27	





# **OIL ANALYSIS REPORT**















Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06233948

Test Package : IND 2

: UFD0002164 Unique Number : 11122782

Received : 11 Jul 2024 **Tested** : 12 Jul 2024 Diagnosed

: 12 Jul 2024 - Wes Davis

US 60143 Contact: ED DIENER ed.diener@fluidairedynamics.com

**FLUID-AIRE DYNAMICS** 

225 SPRING LAKE DR

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCFLUSCH [WUSCAR] 06233948 (Generated: 07/12/2024 16:17:41) Rev: 1

Contact/Location: ED DIENER - UCFLUSCH

T: (847)678-8388

ITASCA, IL