

OIL ANALYSIS REPORT

Area PG46 [SO-292909] PNEUTECH AK10006060 - HONEYWELL

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) COMPRESSOR OIL (PAO) ISO 46. Please confirm.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL


SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001880		
Sample Date		Client Info		02 Jul 2024		
Machine Age	hrs	Client Info		32480		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	1	0		
Barium	ppm	ASTM D5185m	1	0		
Molybdenum	ppm	ASTM D5185m	1	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	1	0		
Calcium	ppm	ASTM D5185m	1	0		
Phosphorus	ppm	ASTM D5185m	800	522		
Zinc	ppm	ASTM D5185m	20	13		
Sulfur	ppm	ASTM D5185m	37	16		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.24	0.18		



OIL ANALYSIS REPORT

VISUAL





	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
Jul2/24	Odor		*Visual	NORML			
		scalar			NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
1	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT	IES	method				history2
	Visc @ 40°C	cSt	ASTM D445	46	48.7		
	SAMPLE IMAGES	;	method	limit/base	current	history1	history2
Jui2/24 +	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Metals	5		Jul2/24			
	Ed 4			Jui2/24			
	Viscosity @ 40°C				Acid Number		
	Abnormal			Ē ^{0.50}			
	-			(B) 0.50 (B) 0.4(B) 0.30 (B) 0.30 (B) 0.30 (B) 0.20 (C) 0.10 (C) P (C) 0.10 (C) P (C) 0.10 (C) P (C) 0.50 (C) 0.50 (C) 0.4(C) 0.4(C) 0.4(C)+		
	250 99 85 45			<u>ட</u> 0.30 ங	Base		
	3 45 - P			- g 0.20) +		
	Abnormal			2 0.10	Abnormal		
	404				54 1 1		
	Jul2/24			Jul2/24	Jul2/24		
	: WearCheck USA - 501 Madison Ave., Cary, NC 27513 FLUID- : UFD0001880 Received : 11 Jul 2024 225 S : 06233951 Tested : 12 Jul 2024 : 11122785 Diagnosed : 12 Jul 2024 - Wes Davis : IND 2 Cor						

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

۰.

Contact/Location: ED DIENER - UCFLUSCH

F: