




PROBLEM SUMMARY

Sample Rating Trend






WATER



Area
RP-101
 Machine Id
B57035 CAKE TRANSFER SCREW
 Component
Gearbox
 Fluid
PETRO CANADA ENDURATEX EP 320 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where dirt can enter the system. We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	ABNORMAL
Silicon	ppm	ASTM D5185m	>50	▲ 116	▲ 53	▲ 30
Water	%	ASTM D6304	>0.2	▲ 2.28	▲ 1.33	▲ 0.309
ppm Water	ppm	ASTM D6304	>2000	▲ 22800	▲ 13300	▲ 3090
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	▲ 0.2%	▲ 0.2%

Customer Id: HORAUS
 Sample No.: WC0943447
 Lab Number: 06234862
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Dirt Access	---	---	?	We advise that you check all areas where dirt can enter the system.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

WATER



28 Apr 2024 Diag: Don Baldrige

We advise that you check all areas where dirt can enter the system. We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count. All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress. The AN level is acceptable for this fluid.

view report



WATER



05 Jan 2024 Diag: Doug Bogart

We advise that you check for the source of water entry. Resample at the next service interval to monitor. There is too much water present in this sample to perform a particle count. Gear wear is indicated. Appearance is milky. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



WATER



13 Oct 2023 Diag: Don Baldrige

We advise that you check for the source of water entry. Resample at the next service interval to monitor. There is too much water present in this sample to perform a particle count. All component wear rates are normal. Appearance is milky. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
RP-101
 Machine Id
B57035 CAKE TRANSFER SCREW
 Component
Gearbox
 Fluid
PETRO CANADA ENDURATEX EP 320 (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check all areas where dirt can enter the system. We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

● Wear

All component wear rates are normal.

▲ Contamination

Appearance is milky. There is a high concentration of water present in the oil. Elemental levels of silicon (Si) and aluminum (Al) indicate alumina-silicate (coarse dirt) ingress.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0943447	WC0930371	WC0880543
Sample Date	Client Info		09 Jul 2024	28 Apr 2024	05 Jan 2024
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	120	112	▲ 299
Chromium	ppm	ASTM D5185m >15	0	0	1
Nickel	ppm	ASTM D5185m >15	0	0	<1
Titanium	ppm	ASTM D5185m	<1	0	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	44	18	5
Lead	ppm	ASTM D5185m >100	0	0	<1
Copper	ppm	ASTM D5185m >200	<1	<1	2
Tin	ppm	ASTM D5185m >25	<1	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 55	29	38	29
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m 0	1	1	4
Magnesium	ppm	ASTM D5185m 0	2	<1	9
Calcium	ppm	ASTM D5185m 0	286	130	93
Phosphorus	ppm	ASTM D5185m 240	379	391	558
Zinc	ppm	ASTM D5185m 1	26	41	122
Sulfur	ppm	ASTM D5185m 13700	18195	5991	7266

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	116	53	30
Sodium	ppm	ASTM D5185m	27	11	10
Potassium	ppm	ASTM D5185m >20	16	6	5
Water	%	ASTM D6304 >0.2	2.28	1.33	0.309
ppm Water	ppm	ASTM D6304 >2000	22800	13300	3090

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	1.21	1.26	1.57




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	MILKY	MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	0.2%
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 325	320	336	329

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0943447
 Lab Number : 06234862
 Unique Number : 11123696
 Test Package : IND 2 (Additional Tests: KF, PrtCount)
 Received : 12 Jul 2024
 Tested : 15 Jul 2024
 Diagnosed : 15 Jul 2024 - Don Baldrige

HORMEL FOODS - AUSTIN
 1101 NORTH MAIN ST
 AUSTIN, MN
 US 55912
 Contact: RYAN LOWE
 rslowe@hormel.com
 T: (507)437-5674
 F: (507)437-9805

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)