



# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id

**DC/AI/R-141**

Component

**Gearbox**

Fluid

**ROYAL PURPLE SYNFILM GT 220 (--- LTR)**

### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0932123</b>	WC0695168	---
Sample Date	Client Info		<b>24 Jun 2024</b>	30 May 2022	---
Machine Age	hrs	Client Info	<b>0</b>	0	---
Oil Age	hrs	Client Info	<b>5000</b>	2000	---
Oil Changed	Client Info		<b>N/A</b>	N/A	---
Sample Status			<b>ABNORMAL</b>	ABNORMAL	---

### CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.2	<b>NEG</b>	NEG	---

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	<b>2</b>	3	---
Chromium	ppm	ASTM D5185m >15	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m	<b>0</b>	0	---
Silver	ppm	ASTM D5185m	<b>0</b>	<1	---
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	<1	---
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	---
Copper	ppm	ASTM D5185m >200	<b>0</b>	1	---
Tin	ppm	ASTM D5185m >25	<b>0</b>	0	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	---

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>&lt;1</b>	7	---
Barium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Molybdenum	ppm	ASTM D5185m	<b>13</b>	29	---
Manganese	ppm	ASTM D5185m	<b>0</b>	0	---
Magnesium	ppm	ASTM D5185m	<b>74</b>	69	---
Calcium	ppm	ASTM D5185m	<b>4</b>	4	---
Phosphorus	ppm	ASTM D5185m	<b>28</b>	37	---
Zinc	ppm	ASTM D5185m	<b>0</b>	1	---
Sulfur	ppm	ASTM D5185m	<b>20217</b>	20836	---

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	2	---
Sodium	ppm	ASTM D5185m	<b>2</b>	1	---
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	---






### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>▲ 88868</b>	▲ 142658	---
Particles >6µm	ASTM D7647	>5000	<b>● 6291</b>	▲ 26525	---
Particles >14µm	ASTM D7647	>640	<b>74</b>	474	---
Particles >21µm	ASTM D7647	>160	<b>19</b>	108	---
Particles >38µm	ASTM D7647	>40	<b>1</b>	11	---
Particles >71µm	ASTM D7647	>10	<b>0</b>	2	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 24/20/13</b>	▲ 24/22/16	---

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.31</b>	0.40	---

# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	232	---
Visc @ 100°C	cSt	ASTM D445	22.0	22.7	---
Viscosity Index (VI)	Scale	ASTM D2270	121	119	---

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0932123      **Received** : 12 Jul 2024  
**Lab Number** : 06234880      **Tested** : 15 Jul 2024  
**Unique Number** : 11123714      **Diagnosed** : 15 Jul 2024 - Don Baldrige  
**Test Package** : PLANT ( Additional Tests: KV100, VI )

**J/POWER-BD**

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: KENTO OKUHARA  
Mitsuo\_Miyahara@jpower.co.jp

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

JP  
T:  
F: x