




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**058CM12051**

Component  
**Turbine**

Fluid  
**ROYAL PURPLE SYNFILM GT 32 (500 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>RP0041033</b>	RP0020489	RP0028193
Sample Date	Client Info	<b>11 Jul 2024</b>	09 Apr 2024	21 Jan 2024
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	<b>0</b>	0
Chromium	ppm	ASTM D5185m >4	<b>0</b>	0
Nickel	ppm	ASTM D5185m >2	<b>0</b>	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0
Silver	ppm	ASTM D5185m	<b>0</b>	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0
Lead	ppm	ASTM D5185m	<b>0</b>	0
Copper	ppm	ASTM D5185m >5	<b>4</b>	0
Tin	ppm	ASTM D5185m >5	<b>0</b>	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0
Barium	ppm	ASTM D5185m	<b>0</b>	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0
Magnesium	ppm	ASTM D5185m	<b>13</b>	85
Calcium	ppm	ASTM D5185m	<b>&lt;1</b>	3
Phosphorus	ppm	ASTM D5185m	<b>1</b>	0
Zinc	ppm	ASTM D5185m	<b>0</b>	0

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>2</b>	<1
Sodium	ppm	ASTM D5185m	<b>4</b>	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0
Water	%	ASTM D6304 >0.03	<b>0.010</b>	0.028
ppm Water	ppm	ASTM D6304 >300	<b>104</b>	282






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>1644</b>	4272	---
Particles >6µm	ASTM D7647 >1300	<b>556</b>	1175	---
Particles >14µm	ASTM D7647 >160	<b>41</b>	81	---
Particles >21µm	ASTM D7647 >40	<b>10</b>	23	---
Particles >38µm	ASTM D7647 >10	<b>0</b>	2	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >--/17/14	<b>18/16/13</b>	19/17/14	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.31</b>	0.41


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32	32.0	32.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0041033 **Received** : 12 Jul 2024  
**Lab Number** : 06234932 **Tested** : 15 Jul 2024  
**Unique Number** : 11123766 **Diagnosed** : 15 Jul 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**ENTERPRISE PRODUCTS**  
P.O. BOX 573  
MONT BELVIEU, TX  
US 77580  
Contact: TOMMY EDWARDS  
tedwards@eprod.com  
T: (281)217-1411  
F: (281)385-4327

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)