




PROBLEM SUMMARY

Machine Id
GE Unit # 4 Governor Sump
 Component
Governor System
 Fluid
PETRO CANADA TURBOFLO R&O 68 (1000 GAL)

Sample Rating Trend




OFF SPEC



COMPONENT CONDITION SUMMARY

▲ Water Separability



RECOMMENDATION

We recommend that you perform vacuum distillation and/or air drying to attempt to remove any residual water and/or entrained gases from this oil that may be contributing to abnormal foaming and/or poor water separability. We recommend that you investigate the system for introduction of a surfactant to the reservoir. Some potential surfactants include incorrect oil make-up with an oil containing emulsifying agents (engine oil, compressor oil, gear oil), or soaps entering the system after wash down. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Air Release, Foam Tendency, and Water Separability tests and evaluation performed at WearCheck Canada.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	SEVERE	SEVERE	
Separability	oil/h2o/em	*ASTM D1401	41/39/0	▲ 27/18/35 (30)	▲ 38/34/8 (30)	▲ 25/19/36 (30)
Air Release Time	min	*ASTM D3427	8	▲ 9.50	9.90	▲ 11.2
Foam Stability	I/II/III	*ASTM D892	0	▲ 30/0/30	0/0/0	0/0/0

Customer Id: USAHEN
 Sample No.: KFS0006621
 Lab Number: 06234947
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We recommend an early resample to monitor this condition.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Filter Fluid	---	---	?	We recommend that you perform vacuum distillation and/or air drying to attempt to remove any residual water and/or entrained gases from this oil that may be contributing to abnormal foaming and/or poor water separability.

HISTORICAL DIAGNOSIS

CONTAMINANT



31 May 2024 Diag: Doug Bogart

Recommend Varnish Potential testing (MPC). Air Release, Foam Tendency, and Water Separability tests and evaluation performed at WearCheck Canada.{not applicable} Separability (Emulsion) % is severely high. Separability (Water) % is severely low. Separability (Oil) % is marginally low. Separability % is severely low.

[view report](#)



CONTAMINANT



30 Apr 2024 Diag: Doug Bogart

This is a baseline read-out on the submitted sample. All tests and evaluation performed at WearCheck Canada.{not applicable} Separability (Emulsion) % is severely high. Separability (Oil) % is severely low. Separability (Water) % is severely low. Separability % is severely low. Air Release Time % is abnormal.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



OFF SPEC



Machine Id

GE Unit # 4 Governor Sump

Component

Governor System

Fluid

PETRO CANADA TURBOFLO R&O 68 (1000 GAL)

DIAGNOSIS

Recommendation

We recommend that you perform vacuum distillation and/or air drying to attempt to remove any residual water and/or entrained gases from this oil that may be contributing to abnormal foaming and/or poor water separability. We recommend that you investigate the system for introduction of a surfactant to the reservoir. Some potential surfactants include incorrect oil make-up with an oil containing emulsifying agents (engine oil, compressor oil, gear oil), or soaps entering the system after wash down. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Air Release, Foam Tendency, and Water Separability tests and evaluation performed at WearCheck Canada.

Wear

All component wear rates are normal.

Contamination

Water Separability results (ASTM D1401) are poor and indicate that the oil will form emulsions with water. The system cleanliness is acceptable for your target ISO 4406 cleanliness code.

Fluid Condition

The Air Release Value (ASTM D3427) indicates the oil has poor deaeration properties. Foaming Stability (ASTM D892) results are abnormal indicating an oil foaming problem that could lead to erratic operation. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0006621	KFS0005997	KFS0005998
Sample Date	Client Info	10 Jul 2024	31 May 2024	30 Apr 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	Not Changed	Not Changed	N/A
Sample Status		SEVERE	SEVERE	SEVERE

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	0	---	---
Iron	ppm	ASTM D5185m >50	<1	0
Chromium	ppm	ASTM D5185m >10	<1	0
Nickel	ppm	ASTM D5185m >10	<1	0
Titanium	ppm	ASTM D5185m	<1	0
Silver	ppm	ASTM D5185m	0	0
Aluminum	ppm	ASTM D5185m >3	<1	0
Lead	ppm	ASTM D5185m >75	1	0
Copper	ppm	ASTM D5185m >15	<1	<1
Tin	ppm	ASTM D5185m >55	0	0
Antimony	ppm	ASTM D5185m >5	0	0
Vanadium	ppm	ASTM D5185m	0	0
Beryllium	ppm	ASTM D5185m	0	0
Cadmium	ppm	ASTM D5185m	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0
Barium	ppm	ASTM D5185m	0	0
Molybdenum	ppm	ASTM D5185m	0	0
Manganese	ppm	ASTM D5185m	0	<1
Magnesium	ppm	ASTM D5185m	0	<1
Calcium	ppm	ASTM D5185m 0	<1	0
Phosphorus	ppm	ASTM D5185m 4	10	5
Zinc	ppm	ASTM D5185m 0	4	0
Sulfur	ppm	ASTM D5185m	176	137
Lithium	ppm	ASTM D5185m	<1	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >8	2	4
Sodium	ppm	ASTM D5185m	0	0
Potassium	ppm	ASTM D5185m >20	0	<1
Water	%	ASTM D6304 >0.1	0.004	---
ppm Water	ppm	ASTM D6304 >1000	45	---


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>1300	281	361
Particles >6µm	ASTM D7647	>320	79	84
Particles >14µm	ASTM D7647	>40	11	4
Particles >21µm	ASTM D7647	>10	2	1
Particles >38µm	ASTM D7647	>3	0	0
Particles >71µm	ASTM D7647	>3	0	0





Oil Cleanliness	ISO 4406 (c)	>17/15/12	15/13/11	16/14/9	14/13/10
-----------------	--------------	-----------	----------	---------	----------

OIL ANALYSIS REPORT

▲ Foaming SEQ I/II/III



▲ Water Separability



FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.11	0.08	0.066	0.05

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	64.9	64.9	65.0	64.63
Separability	oil/h2o/em	*ASTM D1401	41/39/0	▲ 27/18/35 (30)	▲ 38/34/8 (30)	▲ 25/19/36 (30)
Air Release Time	min	*ASTM D3427	8	▲ 9.50	9.90	▲ 11.2
Foam Tendency	I/II/III	*ASTM D892	10	▲ 350/80/340	260/70/270	10/70/10
Foam Stability	I/II/III	*ASTM D892	0	▲ 30/0/30	0/0/0	0/0/0

SAMPLE IMAGES



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KFS0006621
Lab Number : **06234947**
Unique Number : 11123781
Test Package : PLANT (Additional Tests: AirRelease, Foaming, H2OSeparability, KF, PrtCo00t)act: Service Manager

US ARMY CORPS OF ENGINEERS - OLD HICKORY
 10 POWER PLANT RD
 HENDERSONVILLE, TN
 US 37075

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: