


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

## **KAESER 8812024**

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Nov2023	Jun2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA019379	KCPA011333	
Sample Date		Client Info		24 Jun 2024	08 Nov 2023	
Machine Age	hrs	Client Info		3975	1778	
Oil Age	hrs	Client Info		3975	814	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	2	
Chromium	ppm	ASTM D5185m	>10	0	<1	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m		8	2	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	1	0	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m	_	0	0	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		21372	18052	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	nnm	ASTM D5185m	>25	2	2	
Sodium	ppm	ASTM D5185m	725	3	15	
Potassium		ASTM D5185m	>20	1	2	
Water	ppm %	ASTM D5103111	>0.05	0.017	0.029	
ppm Water	ppm	ASTM D6304	>50.05	178	295.3	
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3082	9251	
Particles >6µm		ASTM D7647	>1300	<u>1507</u>	△ 4781	
Particles >14µm		ASTM D7647	>80	61	▲ 318	
Particles >21µm		ASTM D7647		7	△ 67	
Particles >38µm		ASTM D7647	>4	0	3	
Particles >71µm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>19/18/13</b>	△ 20/19/15	
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35	0.32	
ACIO NUMBEI (AN)	my NOT I/g	70 LINI D0043	U. <del>~</del>	0.55	0.02	



## **OIL ANALYSIS REPORT**





Certificate 12367

Laboratory Sample No.

Lab Number : 06234961 Unique Number : 11123795

: KCPA019379 Received : 12 Jul 2024 **Tested** : 15 Jul 2024

: 15 Jul 2024 - Don Baldridge Diagnosed

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

5930 BETHOLD AVE ST. LOUIS, MO US 63110 Contact: JETT

JETT@STLZOO.COM T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: