


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

E-151 (S/N 00645-021-1-01-02)

Component **Gearbox**

USPI 5000 GEAR 220 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		L	Apr2024	Jul2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM37960	USPM36851	
Sample Date		Client Info		11 Jul 2024	28 Apr 2024	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1110	Client Info		N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
						mstoryz
Iron	ppm	ASTM D5185m		34 0	22	
Chromium	ppm	ASTM D5185m	>15	-	<1	
Nickel	ppm	ASTM D5185m	>15	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	٥٢	0	0	
Aluminum	ppm	ASTM D5185m	>25	<1	0	
Lead	ppm	ASTM D5185m	>100	0	0	
Copper	ppm	ASTM D5185m	>200	0	<1	
Tin	ppm	ASTM D5185m	>25	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		0	1	
Phosphorus	ppm	ASTM D5185m		711	159	
Zinc	ppm	ASTM D5185m		12	82	
Sulfur	ppm	ASTM D5185m		1334	1995	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	9	4	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	1	0	
Water	%	ASTM D6304	>0.2	0.006	0.003	
ppm Water	ppm	ASTM D6304	>2000	60	28	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	120354	△ 95533	
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>15819</u>	
Particles >14µm		ASTM D7647	>160	1 715	160	
Particles >21µm		ASTM D7647	>40	<u> </u>	22	
Particles >38µm		ASTM D7647	>10	5	1	
Particles >71μm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>4</u> 24/21/17	<u>4</u> 24/21/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.46	0.23	



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06234975 Unique Number : 11123809

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USPM37960

Received : 12 Jul 2024 Tested : 15 Jul 2024

Diagnosed : 15 Jul 2024 - Doug Bogart

SIOUXPREME PACKAGING COMPANY 2800 MURRAY STREET

SIOUX CITY, IA US 51111

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: