




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

FP60

Component

Diesel Engine

Fluid

DIESEL ENGINE OIL SAE 40 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0014468	KL0014467	KL0014466
Sample Date	Client Info		02 Jul 2024	21 Jun 2024	18 Jun 2024
Machine Age	hrs	Client Info	12212	11952	11879
Oil Age	hrs	Client Info	374	114	40
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			ATTENTION	ATTENTION	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	<1.0	<1.0
Water	WC Method	>0.2	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >100	4	<1	0
Chromium	ppm	ASTM D5185m >20	0	0	0
Nickel	ppm	ASTM D5185m >4	0	0	<1
Titanium	ppm	ASTM D5185m	<1	<1	<1
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >20	2	<1	<1
Lead	ppm	ASTM D5185m >40	0	0	0
Copper	ppm	ASTM D5185m >330	<1	0	0
Tin	ppm	ASTM D5185m >15	<1	0	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 250	76	83	86
Barium	ppm	ASTM D5185m 10	0	0	0
Molybdenum	ppm	ASTM D5185m 100	<1	0	0
Manganese	ppm	ASTM D5185m	0	<1	<1
Magnesium	ppm	ASTM D5185m 450	729	715	733
Calcium	ppm	ASTM D5185m 3000	1470	1378	1411
Phosphorus	ppm	ASTM D5185m 1150	1136	1068	1089
Zinc	ppm	ASTM D5185m 1350	1333	1201	1251
Sulfur	ppm	ASTM D5185m 4250	5518	5109	5266

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	4	3	4
Sodium	ppm	ASTM D5185m >216	<1	2	2
Potassium	ppm	ASTM D5185m >20	2	2	3

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	0.2	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >20	9.1	6.3	6.0
Sulfation	Abs/.1mm	*ASTM D7415 >30	21.4	18.6	18.5



OIL ANALYSIS REPORT







FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	7586	8647	13998
Particles >6µm	ASTM D7647	>5000	4133	4711	7625
Particles >14µm	ASTM D7647	>640	703	802	1298
Particles >21µm	ASTM D7647	>160	237	270	437
Particles >38µm	ASTM D7647	>40	37	42	67
Particles >71µm	ASTM D7647	>10	4	4	7
Oil Cleanliness	ISO 4406 (c)	>21/19/16	20/19/17	20/19/17	21/20/17

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414	>25	14.5	12.1	12.1
Base Number (BN)	mg KOH/g ASTM D2896	8.5	10.26	10.13	9.93

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	LIGHT	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual	>0.2	NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt ASTM D445	14.4	13.9	14.1	14.3

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : KL0014468

Lab Number : 06235120

Unique Number : 11123954

Test Package : MOB 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 12 Jul 2024

Tested : 15 Jul 2024

Diagnosed : 15 Jul 2024 - Sean Felton

IRON CLAD ENERGY

9015 W COUNTY RD 127

MIDLAND, TX

US 79706

Contact: TREVOR FRENETTE

T:

F: