


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SFC 110S 5854832 (S/N 1042)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan2018	May2019 Oct2020	Nov2021 Nov2022 Fe	2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA020586	KCPA015814	KCPA000186
Sample Date		Client Info		28 Jun 2024	22 Feb 2024	02 Mar 2023
Machine Age	hrs	Client Info		29470	28146	22653
Oil Age	hrs	Client Info		0	4546	0
Oil Changed		Client Info		Changed	Not Changd	N/A
Sample Status				ATTENTION	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	2	0
Copper	ppm	ASTM D5185m	>50	11	16	7
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	0	<1	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		18330	15431	17324
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		1	<1	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.007	0.033	0.006
ppm Water	ppm	ASTM D6304	>500	70	339	60.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4264		1392
Particles >6µm		ASTM D7647	>1300	1602		337
Particles >14µm		ASTM D7647	>80	134		41
Particles >21µm		ASTM D7647	>20	24		11
Particles >38µm		ASTM D7647	>4	1		1
Particles >71μm		ASTM D7647	>3	0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/18/14		18/16/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.42	0.45	0.41



OIL ANALYSIS REPORT







Certificate 12367

Sample No.

Laboratory

: KCPA020586 Lab Number : 06235973

Unique Number : 11124807

Received : 15 Jul 2024 **Tested** Diagnosed

: 16 Jul 2024 : 17 Jul 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

7701 SKYLINE PARK DR, BLDG B FORT WORTH, TX

US 76108

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - WEIFOR

T:

F: