


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



CMAR_U4 CMAR_U4_P4

Non-Drive End Pump

ROYAL PURPLE SYNFILM GT 32 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0043877	RP0029030	RP0021298
Sample Date		Client Info		28 Jun 2024	20 Mar 2024	27 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	4	7	5
Chromium	ppm	ASTM D5185m	>5	0	<1	0
Nickel	ppm	ASTM D5185m	>5	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	<1	<1
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	0	1	0
Lead	ppm	ASTM D5185m	>12	0	3	<1
Copper	ppm	ASTM D5185m	>30	19	20	21
Tin	ppm	ASTM D5185m	>9	0	1	<1
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		0	3	1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		0	16	7
Calcium	ppm	ASTM D5185m		0	15	6
Phosphorus	ppm	ASTM D5185m		0	15	0
Zinc	ppm	ASTM D5185m		0	18	9
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	1	3	<1
Sodium	ppm	ASTM D5185m		1	0	1
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>.1	0.006	0.002	0.005
ppm Water	ppm	ASTM D6304	>1000	63	21	57
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.33	0.36	0.32
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG	NEG


Ibmittec By: NATHAN E OLMES


NEG


scalar *Visual



OIL ANALYSIS REPORT












GRAPHS Ferrous Alloys











Certificate 12367

Laboratory Sample No.

: RP0043877 Lab Number : 06236134 Unique Number : 11124968

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received **Tested** Diagnosed

: 15 Jul 2024 : 16 Jul 2024

: 17 Jul 2024 - Don Baldridge

ENERGY TRANSFER - MARYSVILLE 250 MURPHY DRIVE

ST. CLAIR, MI US 48079

T: (313)580-0267

Contact: SCOTT VERHELLE

Submitted By: NATHAN HOLMES

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: ENESAI [WUSCAR] 06236134 (Generated: 07/17/2024 12:07:41) Rev: 1

F: