

## **OIL ANALYSIS REPORT**

Sample Rating Trend

NORMAL

### Area NOT GIVEN [293082] ATLAS COPCO API329770

Component Compressor

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>/IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0002354		
Sample Date		Client Info		03 Jun 2024		
Machine Age	hrs	Client Info		2000		
Oil Age	hrs	Client Info		2000		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	0		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	<1		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		1		
Phosphorus	ppm	ASTM D5185m		181		
Zinc	ppm	ASTM D5185m		56		
Sulfur	ppm	ASTM D5185m		119		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	2		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.10		



Jun3/24

# **OIL ANALYSIS REPORT**



Laboratory Sample No. Lab Number Unique Number Test Package To discuss this sample report,			arCheck USA - 50 D0002354	1 Madisc Rece Teste	ived : 15			<b>FLUID-AIRE DYNAMICS - (MN)</b> 14250 JUDICIAL ROAD BURNSVILLE, MN US 55306 Contact: Service Manager		
		55 - 50 - (2.04) 45 - 40 - 35 -	Viscosity @ 40°C			Jun3/24 Jun3/2	Acid Number	ir	Jun324	
			Non-ferrous Metal	S						
		10 - 8 - Ed. 6 - 2 - 0	GRAPHS Ferrous Alloys			Jun3/24				
	-	В	ottom					no image	no image	
	Jun3/24		SAMPLE IMAGES	3	method	limit/base	current	history1	history2 no image	
			FLUID PROPERT	cSt	method ASTM D445	limit/base	current 43.8	history1	history2	
			ree Water	scalar	*Visual		NEG			
	Jun3/24	0	ndor mulsified Water	scalar scalar	*Visual *Visual	NORML >0.1	NORML			
	24	S	ebris and/Dirt ppearance	scalar scalar scalar	*Visual *Visual *Visual	NONE NORML	NONE NONE NORML			
		S	recipitate ilt	scalar scalar	*Visual *Visual	NONE NONE	NONE NONE			
			/hite Metal ellow Metal	scalar scalar	*Visual *Visual	NONE NONE	NONE NONE			

Contact/Location: Service Manager - UCFLUBUR Page 2 of 2