

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id HBKM01BE Component Biogas Engine

SHELL MYSELLA S5 S (160 GAL)

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMFLE INFORM	ATION	method	iiiiii/base	current	nistory i	TIIStOryz
Sample Number		Client Info		WC0775163	WC0775489	WC0775487
Sample Date		Client Info		11 Jul 2024	01 Jul 2024	26 Jun 2024
Machine Age	hrs	Client Info		111290	111087	110973
Oil Age	hrs	Client Info		271	68	871
Oil Changed		Client Info		Changed	Changed	Oil Added
Sample Status				NORMAL	NORMAL	SEVERE
CONTAMINATION	J	method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method		NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		16	14	20
Iron	ppm	ASTM D5185m	>14	2	1	7
Chromium	ppm	ASTM D5185m	>3	0	0	<1
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>5	2	2	4
Lead	ppm	ASTM D5185m	>8	0	0	<1
Copper	ppm	ASTM D5185m	>5	<1	<1	3
Tin	ppm	ASTM D5185m	>3	<1	0	<u> </u>
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	historv1	historv2
Boron	ppm	ASTM D5185m		88	136	51
Barium	maa	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		1	2	3
Manganese	ppm	ASTM D5185m		0	<1	1
Magnesium	maa	ASTM D5185m		15	9	25
Calcium	mag	ASTM D5185m		1697	1792	1730
Phosphorus	maa	ASTM D5185m	300	434	477	403
Zinc	maa	ASTM D5185m		547	555	540
Sulfur	ppm	ASTM D5185m		3875	3944	3987
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>180	115	44	2 26
Sodium	ppm	ASTM D5185m	>20	2	2	4
Potassium	ppm	ASTM D5185m	>20	0	0	4
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624		4.1	3.3	5.5
Sulfation	Abs/.1mm	*ASTM D7415		18.2	16.3	22.6
		•				



OIL ANALYSIS REPORT









FLUID DEGRADA	TION	method				history2
Oxidation	Abs/.1mm	*ASTM D7414		11.4	9.4	16.9
Acid Number (AN)	mg KOH/g	ASTM D8045		0.64	1.06	1.66
Base Number (BN)	mg KOH/g	ASTM D2896	5.3	4.40	5.31	3.61
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual		NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	14.4	14.0	14.3





Apr2/24

Aav10/24

Jun 10/24

eb14/24





Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 **EDL NA Recips-Honeybrook** Sample No. : WC0775163 Received : 15 Jul 2024 Honey Brook Powerstation, 481 S. Churchtown Road Lab Number : 06236244 Tested : 16 Jul 2024 Unique Number : 11125078 Diagnosed : 16 Jul 2024 - Sean Felton Test Package : MOB 2 (Additional Tests: PQ) **Contact: Christian Adames** Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. Christian.Adames@edlenergy.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Dec6/23

an 10/74

Sen75/73

Report Id: EDLNAR [WUSCAR] 06236244 (Generated: 07/16/2024 14:31:41) Rev: 1

Submitted By: Danny Hernandez Page 2 of 2

Narvon, PA

T:

F:

US 17555-9574