


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

2484328 (S/N 1005)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Oct2016	Dec2017 Dec2018	Feb2021 Feb2023 Feb2023	Jul2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016008	KCP55810	KCP55806
Sample Date		Client Info		09 Jul 2024	13 Feb 2023	13 Feb 2023
Machine Age	hrs	Client Info		37792	34641	34641
Oil Age	hrs	Client Info		4000	2000	2000
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	12	5	7
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	2	21	6
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	4	3
Zinc	ppm	ASTM D5185m	0	9	23	28
Sulfur	ppm	ASTM D5185m	23500	21394	19820	20759
CONTAMINANTS	1	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		1	3	0
Potassium	ppm	ASTM D5185m	>20	0	3	2
Water	%	ASTM D6304	>0.05	0.009	0.013	0.008
ppm Water	ppm	ASTM D6304	>500	90	132.3	86.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		20694	44343	71667
Particles >6µm		ASTM D7647	>1300	<u></u> 9404	<u>▲</u> 13267	▲ 33052
Particles >14μm		ASTM D7647	>80	1398	△ 925	▲ 4962
Particles >21μm		ASTM D7647	>20	413	<u>^</u> 221	1390
Particles >38μm		ASTM D7647	>4	<u>25</u>	3	<u>^</u> 21
Particles >71µm		ASTM D7647	>3	2	0	1
. a						
Oil Cleanliness		ISO 4406 (c)	>17/13	<u>^</u> 20/18	<u>△</u> 21/17	<u>22/19</u>



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA016008

: 06236821 Unique Number : 11125655

Received : 15 Jul 2024 **Tested** : 17 Jul 2024

: 17 Jul 2024 - Don Baldridge Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

V&H INC - ASSEMBLY SYSTEMS

1505 S CENTRAL AVE MARSHFIELD, WI US 54449

Contact: KASY LIPINSKI

kasy.lipinski@assemblysystems.com

F:

T: