

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id

KAESER SFC 22 4847746 (S/N 1037)

Component Compressor

Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014325	KCP52562	KCP27544
Sample Date		Client Info		28 Jun 2024	24 May 2023	12 Mar 2021
Machine Age	hrs	Client Info		26530	23601	18056
Oil Age	hrs	Client Info		2929	2798	2356
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		۰ <1	<1	1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper		ASTM D5185m		ں <1	5	<1
Tin	ppm	ASTM D5185m		<1	0	<1
	ppm		>10	-		< 1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	10	0	34
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	41	3	80
Calcium	ppm	ASTM D5185m	0	2	0	0
Phosphorus	ppm	ASTM D5185m	0	<1	2	3
Zinc	ppm	ASTM D5185m	0	4	2	0
Sulfur	ppm	ASTM D5185m	23500	21268	23671	16589
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	<1	<1
Sodium	ppm	ASTM D5185m		- 14	3	12
Potassium	ppm	ASTM D5185m	>20	2	2	2
Water	%	ASTM D6304		0.015	0.009	0.024
ppm Water	ppm	ASTM D6304	>500	157	96.7	247.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		150651	3242	6500
Particles >6µm		ASTM D7647	>1300	<u> </u>	765	2220
Particles >14µm		ASTM D7647	>80	▲ 5374	50	128
Particles >21µm		ASTM D7647		<u> </u>	10	27
Particles >38µm		ASTM D7647	>4	▲ 30	1	3
Particles >71µm		ASTM D7647		2	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	19/17/13	18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
- LOID DEGINADA		HIGHIUU	unit/base		IIISTOLA I	11510172

Report Id: SKYWHE [WUSCAR] 06236826 (Generated: 07/17/2024 14:59:46) Rev: 1

Contact/Location: Service Manager - SKYWHE



OIL ANALYSIS REPORT

method

*Visual

*Visual

scalar

scalar

limit/base

NONE

NONE

current

NONE

NONE

history1


NONE


NONE

history2

NONE

NONE





E 0.72


ළි 0.48

2 0.24

0.00 PC

Aug7

Jun28/24



Oct15/19

Water (KF)

Abnormal

1000

600 Water (

4000

200

muu

Mar12/21

Mav24/23





: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 Jul 2024 Tested : 17 Jul 2024 Diagnosed

May24/23

: 17 Jul 2024 - Don Baldridge

SKYLINE ENTERPRISES INC

May24/23

in 28/24

T:

F:

S 55

45

40

35

Abnorma

Seve

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Mar12/21

Contact/Location: Service Manager - SKYWHE Page 2 of 2

Mar12/21.

⁴⁹⁸⁰ OAK ST WHEAT RIDGE, CO US 80033 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

^{* -} Denotes test methods that are outside of the ISO 17025 scope of accreditation.