

OIL ANALYSIS REPORT

Sample Rating Trend WATER

Machine Id KAESER AIRCENTER SM 7.5 3895008 (S/N 1101) Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC132373	KCPA005945	KCP52011
Sample Date		Client Info		10 Jul 2024	03 Aug 2023	27 Nov 2022
Machine Age	hrs	Client Info		33070	29881	27515
Oil Age	hrs	Client Info		4000	0	6000
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		14	4	10
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m	-			
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES	pp	method	limit/base		-	-
			limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	00	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m	0.0	0	<1	<1
Magnesium	ppm	ASTM D5185m	90	3	13	11
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		2	3	30
Zinc	ppm	ASTM D5185m		59	69	78
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	<1	<1
Sodium	ppm	ASTM D5185m		1	<1	4
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.05	<u> </u>	0.271	0.011
ppm Water	ppm	ASTM D6304	>500	1380	2 710	119.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647				4586
Particles >6µm		ASTM D7647	>1300			<u> </u>
Particles >14µm		ASTM D7647	>80			04
Particles >21µm		ASTM D7647	>20			24
Particles >38µm		ASTM D7647	>4			3
Particles >71µm		ASTM D7647	>3			0
Oil Cleanliness		ISO 4406 (c)	>17/13			9/18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.25	0.28	0.30


Contact/Location: DALE ? - URBSTL Page 1 of 2




Built for a lifetime.

OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	A MODER	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	- HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	0.0	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.2	43.8	44.3
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						

Bottom



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: URBSTL [WUSCAR] 06236843 (Generated: 07/17/2024 14:52:53) Rev: 1

Certificate 12367

Contact/Location: DALE ? - URBSTL

Page 2 of 2

T:

F: