


OIL ANALYSIS REPORT

Sample Rating Trend







DIAMOND BLUE 8K SULLAIR 200803060113 - BUZZI

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		JHF06236935	UCH06186792	UCH0000527
Sample Date		Client Info		01 Jul 2024	29 Apr 2024	15 Jan 2024
Machine Age	hrs	Client Info		101504	101743	99760
Oil Age	hrs	Client Info		6201	6440	4457
Oil Changed		Client Info		Changed	Not Changd	Oil Added
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	<1
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>25	0	0	<1
Lead	ppm	ASTM D5185m	>25	0	1	0
Copper	ppm	ASTM D5185m	>50	12	13	9
Tin	ppm	ASTM D5185m	>15	<1	1	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		57	84	17
Molybdenum	ppm	ASTM D5185m		<1	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		0	<1	1
Calcium	ppm	ASTM D5185m		29	35	45
Phosphorus	ppm	ASTM D5185m		4	0	2
Zinc	ppm	ASTM D5185m		0	8	0
Sulfur	ppm	ASTM D5185m		176	75	127
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		63	57	64
Potassium	ppm	ASTM D5185m	>20	5	4	3
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.73	0.57	0.41



OIL ANALYSIS REPORT



	/	/	. 1	1			
Abnormal	/	~	AV	1	~	1	
- 1						1	,
Achormal						1	_

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
ELLID DDODEDT		l	Para St. /leanna		la fact a smooth	la la marco


I LOID I NOI L	ITTILO	memou		HISTOLAL	riistory
Visc @ 40°C	cSt	ASTM D445	44.0	44.3	42.4


SAMPLE IMAGES	method				history2
---------------	--------	--	--	--	----------


Color


Bottom















Laboratory Sample No.

: JHF06236935 Lab Number : 06236935

Unique Number : 11125769

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 15 Jul 2024

Tested : 17 Jul 2024 Diagnosed : 17 Jul 2024 - Wes Davis

SAINT LOUIS, MO US 63134

4700 LEBOURGET STREET

JOHN HENRY FOSTER COMPANY

Contact: RACHEL VON HATTEN rvonhatten@jhf.com

T: (314)593-1267 F: (314)874-0965

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)