


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

112CM12.008

Component **Turbine**

ROYAL PURPLE SYNFILM GT 32 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		lul2001 No	v/2001 May2002 Se	p2002 Jan2003 Mar2003	Jul2003	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0027325	RP022413	RP022454
Sample Date		Client Info		15 Jul 2024	29 Jul 2003	04 Jun 2003
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				MARGINAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	<1	1	1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m		0	0	0
Copper	ppm	ASTM D5185m	>5	0	4	3
Tin	ppm	ASTM D5185m	>5	<1	0	0
Antimony	ppm	ASTM D5185m			0	1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		3	80	69
Calcium	ppm	ASTM D5185m		0	2	0
Phosphorus	ppm	ASTM D5185m		2166	0	0
Zinc	ppm	ASTM D5185m		0	2	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	2	1
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water	%	ASTM D6304	>0.03	△ 0.113	0.012	0.013
ppm Water	ppm	ASTM D6304	>300	<u> </u>		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1104	7382	3016
Particles >6µm		ASTM D7647	>1300	236	<u></u>	1030
Particles >14µm		ASTM D7647	>160	10	△ 351	155
Particles >21µm		ASTM D7647	>40	3	△ 31	19
Particles >38µm		ASTM D7647	>10	0	1	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/14	17/15/10	△ 20/19/16	19/17/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Asid Number (AN)		AOTA DOO45		0.71	0.050	0.400

Acid Number (AN)

mg KOH/g ASTM D8045

0.350

0.71

0.429



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

: RP0027325 : 06237778 Unique Number : 11126612

Received : 16 Jul 2024 **Tested** : 17 Jul 2024 Diagnosed

: 18 Jul 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (281)217-1411 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (281)385-4327

P.O. BOX 573

US 77580

MONT BELVIEU, TX

tedwards@eprod.com

Contact: TOMMY EDWARDS