



# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**TM 11**  
 Machine Id  
**TM 11 PRESSURE ROLL REDUCER**  
 Component  
**Gearbox**  
 Fluid  
**ROYAL PURPLE SYNERGY 90/220 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>RP0038098</b>	RP0037973	RP0034371
Sample Date	Client Info	<b>15 Jul 2024</b>	30 Jan 2024	08 Aug 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	ATTENTION	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	<b>16</b>	15	14	
Iron	ppm	ASTM D5185m >200	<b>11</b>	7	67
Chromium	ppm	ASTM D5185m >15	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	4
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>0</b>	<1	2
Tin	ppm	ASTM D5185m >25	<b>0</b>	<1	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	9	22
Barium	ppm	ASTM D5185m	<b>0</b>	0	19
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>1</b>	0	0
Calcium	ppm	ASTM D5185m	<b>2</b>	60	<1
Phosphorus	ppm	ASTM D5185m 370	<b>441</b>	401	238
Zinc	ppm	ASTM D5185m	<b>55</b>	56	26

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>24</b>	17	3
Sodium	ppm	ASTM D5185m	<b>2</b>	2	3
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Water	%	ASTM D6304 >0.2	<b>0.015</b>	0.021	0.016
ppm Water	ppm	ASTM D6304 >2000	<b>151</b>	219	165.1






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	<b>8578</b>	19868	▲ 129997
Particles >6µm	ASTM D7647 >5000	<b>3001</b>	● 5005	▲ 41343
Particles >14µm	ASTM D7647 >640	<b>547</b>	503	▲ 1992
Particles >21µm	ASTM D7647 >160	<b>148</b>	130	▲ 592
Particles >38µm	ASTM D7647 >40	<b>7</b>	8	29
Particles >71µm	ASTM D7647 >10	<b>1</b>	1	2
Oil Cleanliness	ISO 4406 (c) >21/19/16	<b>20/19/16</b>	● 21/20/16	▲ 24/23/18

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 1.33	<b>1.32</b>	1.26	1.52


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	216.1	210	216

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0038098 **Received** : 16 Jul 2024  
**Lab Number** : 06237793 **Tested** : 17 Jul 2024  
**Unique Number** : 11126627 **Diagnosed** : 18 Jul 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: PQ, PrtCount )

**Kimberly-Clark - Mobile - TM 11**  
 200 BAYBRIDGE RD  
 MOBILE, AL  
 US 36610  
 Contact: LARRY WEAVER  
 Larry.D.Weaver@kcc.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (251)452-6335