

PROBLEM SUMMARY








TM 11 Machine Id TM 11 YANKEE REDUCER Component

Gearbox

ROYAL PURPLE SYNERGY 140/320 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			SEVERE	ATTENTION	NORMAL				
Particles >4µm	ASTM D7647	>20000	▲ 35708	12946	6597				
Particles >6µm	ASTM D7647	>5000	11869	4119	1999				
Particles >14μm	ASTM D7647	>640	4 904	648	403				
Particles >21µm	ASTM D7647	>160	200	131	105				
Oil Cleanliness	ISO 4406 (c)	>21/19/16	22/21/17	21/19/17	20/18/16				

Customer Id: KIMMOBTM11 Sample No.: RP0037901 Lab Number: 06237794 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			_	We recommend you service the filters on this component if applicable.
			?	

HISTORICAL DIAGNOSIS

30 Jan 2024 Diag: Don Baldridge



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Aug 2023 Diag: Angela Borella





Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

TM 11 TM 11 YANKEE REDUCER

Gearbox

ROYAL PURPLE SYNERGY 140/320 (--- GAL)





DIAGNOSIS

▲ Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

AL)		sr2011 Apr20	12 Jul2013 Nov2014	Apr2016 Feb2018 Jun2020	May2023	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0037901	RP0037978	RP0034365
Sample Date		Client Info		15 Jul 2024	30 Jan 2024	08 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		21	17	8
Iron	ppm	ASTM D5185m	>200	5	3	4
Chromium	ppm	ASTM D5185m	>15	0	0	<1
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	1	3	4
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	0	<1
Tin	ppm	ASTM D5185m	>25	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		5	22	28
Barium	ppm	ASTM D5185m		0	0	19
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		1	<1	0
Calcium	ppm	ASTM D5185m		0	0	2
Phosphorus	ppm	ASTM D5185m	200	477	418	435
Zinc	ppm	ASTM D5185m		0	2	32
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	5	3	7
Sodium	ppm	ASTM D5185m		0	<1	1
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304	>0.2	0.020	0.015	0.016
ppm Water	ppm	ASTM D6304	>2000	207	152	166.6
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	35708	12946	6597
Particles >6µm		ASTM D7647	>5000	11869	4119	1999
Particles >14μm		ASTM D7647	>640	4 904	648	403
Particles >21µm		ASTM D7647	>160	200	131	105
Particles >38µm		ASTM D7647	>40	11	3	4
Particles >71μm		ASTM D7647	>10	1	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	22/21/17	21/19/17	20/18/16
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
A 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1/01::	10TH D06 :-				4.00

Acid Number (AN)

mg KOH/g ASTM D8045 1.2

1.41

1.44

1.26



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

: RP0037901 : 06237794 Unique Number: 11126628

Received **Tested** Diagnosed

: 18 Jul 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: PQ, PrtCount)

: 16 Jul 2024

: 17 Jul 2024

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Kimberly-Clark - Mobile - TM 11

200 BAYBRIDGE RD MOBILE, AL US 36610

Contact: LARRY WEAVER Larry.D.Weaver@kcc.com

F: (251)452-6335

T: