




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area

**Fermentation**

Machine Id

**Lightnin FFG33MB01 Main Fermentor, Agitator**

Component

**Gearbox**

Fluid

**JAX FGG-AW ISO 220 (28 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0901917</b>	WC0894973	WC0857613
Sample Date	Client Info	<b>12 Jul 2024</b>	01 May 2024	11 Jan 2024
Machine Age	hrs Client Info	<b>0</b>	0	0
Oil Age	hrs Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >200	<b>4</b>	2	4
Chromium	ppm ASTM D5185m >15	<b>0</b>	0	<1
Nickel	ppm ASTM D5185m >15	<b>0</b>	0	0
Titanium	ppm ASTM D5185m	<b>0</b>	0	<1
Silver	ppm ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm ASTM D5185m >25	<b>0</b>	0	2
Lead	ppm ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm ASTM D5185m >200	<b>0</b>	0	1
Tin	ppm ASTM D5185m >25	<b>0</b>	0	<1
Vanadium	ppm ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<b>0</b>	0	1
Barium	ppm ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m	<b>0</b>	0	<1
Manganese	ppm ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm ASTM D5185m	<b>0</b>	0	0
Calcium	ppm ASTM D5185m	<b>0</b>	<1	3
Phosphorus	ppm ASTM D5185m	<b>577</b>	562	681
Zinc	ppm ASTM D5185m	<b>3</b>	6	0
Sulfur	ppm ASTM D5185m	<b>894</b>	900	980

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	<b>1</b>	<1	1
Sodium	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Potassium	ppm ASTM D5185m >20	<b>0</b>	0	<1
Water	% ASTM D6304 >0.2	<b>0.004</b>	0.011	0.003
ppm Water	ppm ASTM D6304 >2000	<b>49</b>	110	31

## FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	<b>8856</b>	3562	655
Particles >6µm	ASTM D7647 >5000	<b>1501</b>	516	134
Particles >14µm	ASTM D7647 >640	<b>34</b>	24	12
Particles >21µm	ASTM D7647 >160	<b>6</b>	10	4
Particles >38µm	ASTM D7647 >40	<b>0</b>	2	0
Particles >71µm	ASTM D7647 >10	<b>0</b>	1	0
Oil Cleanliness	ISO 4406 (c) >21/19/16	<b>20/18/12</b>	19/16/12	17/14/11

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	<b>0.59</b>	0.68	0.68




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	220	221	227

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0901917 **Received** : 16 Jul 2024  
**Lab Number** : 06237806 **Tested** : 17 Jul 2024  
**Unique Number** : 11126640 **Diagnosed** : 18 Jul 2024 - Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**NOVOZYMES**  
 P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD  
 FRANKLINTON, NC  
 US 27525  
 Contact: BRUCE THOMAS  
 brct@novozymes.com  
 T: (919)494-3146  
 F: (919)494-3456

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)