




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

PNEX

Machine Id

[PNEX] TOTE 23 - TURBINE 150

Component

New (Unused) Oil

Fluid

BELRAY Turbine Oil 150 (275 GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	RP0042862	RP0042879	RP0038971
Sample Date	Client Info	12 Jul 2024	08 Mar 2024	28 Nov 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	Not Changed	Not Changed	Not Changed
Sample Status		ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >5	0	0	0
Chromium	ppm	ASTM D5185m >5	0	0	<1
Nickel	ppm	ASTM D5185m >5	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >5	0	0	0
Aluminum	ppm	ASTM D5185m >5	0	0	2
Lead	ppm	ASTM D5185m >5	0	0	0
Copper	ppm	ASTM D5185m >5	0	0	<1
Tin	ppm	ASTM D5185m >5	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	3
Barium	ppm	ASTM D5185m	<1	0	2
Molybdenum	ppm	ASTM D5185m	0	1	<1
Manganese	ppm	ASTM D5185m	0	0	0
Magnesium	ppm	ASTM D5185m	3	0	30
Calcium	ppm	ASTM D5185m	6	3	57
Phosphorus	ppm	ASTM D5185m	27	19	66
Zinc	ppm	ASTM D5185m	8	0	30

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	<1	2	0
Sodium	ppm	ASTM D5185m	2	0	0
Potassium	ppm	ASTM D5185m >20	<1	0	<1
Water	%	ASTM D6304	0.002	0.002	0.005
ppm Water	ppm	ASTM D6304	19	17	52






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 66580	2804	▲ 113232
Particles >6µm	ASTM D7647 >1300	▲ 10899	467	▲ 51093
Particles >14µm	ASTM D7647 >160	68	24	▲ 2061
Particles >21µm	ASTM D7647 >40	18	4	▲ 48
Particles >38µm	ASTM D7647 >10	2	0	1
Particles >71µm	ASTM D7647 >3	1	0	1
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 23/21/13	19/16/12	▲ 24/23/18

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.079	0.077	0.087

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	142.2	139.6	141.5
Visc @ 100°C	cSt	ASTM D445	14.0	14.02	13.99
Viscosity Index (VI)	Scale	ASTM D2270	99	96	95

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0042862 **Received** : 16 Jul 2024
Lab Number : 06238298 **Tested** : 19 Jul 2024
Unique Number : 11127132 **Diagnosed** : 19 Jul 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: FT-IR, KV100, PrtCount, VI)

CALUMET
 3333 MIDWAY AVENUE
 SHREVEPORT, LA
 US 71109
 Contact: NICHOLAS LESAGE
 nicholas.lesage@clmt.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)