




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

CDW

Machine Id

[CDW] TOTE 22 - TURBINE 100

Component

New (Unused) Oil

Fluid

TURBINE OIL ISO 100 (330 GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	RP0042848	RP0042877	RP0038975
Sample Date	Client Info	12 Jul 2024	08 Mar 2024	28 Nov 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	Not Changed	Not Changd	Not Changed
Sample Status		ABNORMAL	ATTENTION	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >5	0	0
Chromium	ppm	ASTM D5185m >5	0	<1
Nickel	ppm	ASTM D5185m >5	0	0
Titanium	ppm	ASTM D5185m	0	0
Silver	ppm	ASTM D5185m >5	0	0
Aluminum	ppm	ASTM D5185m >5	0	2
Lead	ppm	ASTM D5185m >5	0	0
Copper	ppm	ASTM D5185m >5	0	<1
Tin	ppm	ASTM D5185m >5	0	0
Vanadium	ppm	ASTM D5185m	0	0
Cadmium	ppm	ASTM D5185m	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	1	0
Barium	ppm	ASTM D5185m 5	<1	0
Molybdenum	ppm	ASTM D5185m 5	2	3
Manganese	ppm	ASTM D5185m	0	0
Magnesium	ppm	ASTM D5185m 5	10	0
Calcium	ppm	ASTM D5185m 10	27	5
Phosphorus	ppm	ASTM D5185m 275	41	18
Zinc	ppm	ASTM D5185m 7	22	0

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<1	1
Sodium	ppm	ASTM D5185m	2	0
Potassium	ppm	ASTM D5185m >20	<1	0
Water	%	ASTM D6304	0.002	0.003
ppm Water	ppm	ASTM D6304	17	28

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 15339	● 5705	● 8316
Particles >6µm	ASTM D7647 >1300	▲ 2603	● 1140	● 1885
Particles >14µm	ASTM D7647 >160	129	● 36	● 59
Particles >21µm	ASTM D7647 >40	30	● 3	● 8
Particles >38µm	ASTM D7647 >10	3	● 0	● 1
Particles >71µm	ASTM D7647 >3	0	● 0	● 1
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 21/19/14	● 20/17/12	● 20/18/13

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.13	0.073	0.081

OIL ANALYSIS REPORT


Particle Trend




Water (KF)




Viscosity @ 100°C



Water (KF)




Viscosity @ 100°C







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	97.29	93.3
Visc @ 100°C	cSt	ASTM D445	11.2	11.32	11.01
Viscosity Index (VI)	Scale	ASTM D2270	97	102	101

SAMPLE IMAGES



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0042848 **Received** : 16 Jul 2024
Lab Number : 06238300 **Tested** : 19 Jul 2024
Unique Number : 11127134 **Diagnosed** : 19 Jul 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: FT-IR, KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CALUMET
 3333 MIDWAY AVENUE
 SHREVEPORT, LA
 US 71109
 Contact: NICHOLAS LESAGE
 nicholas.lesage@clmt.com

T:
F: