




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

CDW

Machine Id

[CDW] TOTE 20 - TURBINE 150

Component

New (Unused) Oil

Fluid

BELRAY Turbine Oil 150 (500 GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Contamination

There is a moderate amount of silt (particulates < 6 microns in size) present in the oil.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	RP0042847	RP0042880	RP0038976
Sample Date	Client Info	12 Jul 2024	08 Mar 2024	28 Nov 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	Not Changed	Not Changd	Not Changed
Sample Status		ATTENTION	ATTENTION	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >5	0	0
Chromium	ppm	ASTM D5185m >5	0	<1
Nickel	ppm	ASTM D5185m >5	0	0
Titanium	ppm	ASTM D5185m	0	0
Silver	ppm	ASTM D5185m >5	0	0
Aluminum	ppm	ASTM D5185m >5	0	2
Lead	ppm	ASTM D5185m >5	0	0
Copper	ppm	ASTM D5185m >5	0	<1
Tin	ppm	ASTM D5185m >5	0	0
Vanadium	ppm	ASTM D5185m	0	0
Cadmium	ppm	ASTM D5185m	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0
Barium	ppm	ASTM D5185m	<1	2
Molybdenum	ppm	ASTM D5185m	0	<1
Manganese	ppm	ASTM D5185m	0	0
Magnesium	ppm	ASTM D5185m	3	1
Calcium	ppm	ASTM D5185m	5	3
Phosphorus	ppm	ASTM D5185m	26	10
Zinc	ppm	ASTM D5185m	6	0

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<1	5
Sodium	ppm	ASTM D5185m	2	0
Potassium	ppm	ASTM D5185m >20	0	<1
Water	%	ASTM D6304	0.002	0.001
ppm Water	ppm	ASTM D6304	17	3






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	● 9845	● 5238	▲ 70686
Particles >6µm	ASTM D7647 >1300	● 840	● 498	▲ 21063
Particles >14µm	ASTM D7647 >160	● 19	● 14	● 92
Particles >21µm	ASTM D7647 >40	● 4	● 2	● 11
Particles >38µm	ASTM D7647 >10	● 0	● 1	● 1
Particles >71µm	ASTM D7647 >3	● 0	● 0	● 0
Oil Cleanliness	ISO 4406 (c) >19/17/14	● 20/17/11	● 20/16/11	▲ 23/22/14

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.14	0.088

OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	142.2	139.8	138.5
Visc @ 100°C	cSt	ASTM D445	14.0	13.99	13.88
Viscosity Index (VI)	Scale	ASTM D2270	99	96	96

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0042847 **Received** : 16 Jul 2024
Lab Number : 06238302 **Tested** : 19 Jul 2024
Unique Number : 11127136 **Diagnosed** : 19 Jul 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: FT-IR, KV100, PrtCount, VI)

CALUMET
 3333 MIDWAY AVENUE
 SHREVEPORT, LA
 US 71109
 Contact: NICHOLAS LESAGE
 nicholas.lesage@clmt.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)