


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

7174164 (S/N 1263)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec	.2020	Mar2022 Jul202	4	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014273	KCP43663	KCP34408
Sample Date		Client Info		11 Jul 2024	16 Mar 2022	21 Dec 2020
Machine Age	hrs	Client Info		8803	4877	1945
Oil Age	hrs	Client Info		3000	2000	1000
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	10	2
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	11	8	3
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	10	36	53
Calcium	ppm	ASTM D5185m	0	0	<1	2
Phosphorus	ppm	ASTM D5185m	0	0	<1	7
Zinc	ppm	ASTM D5185m	0	8	17	0
Sulfur	ppm	ASTM D5185m	23500	23179	15531	17290
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		7	12	13
Potassium	ppm	ASTM D5185m	>20	<1	2	1
Water	%	ASTM D6304	>0.05	0.021	0.011	0.018
ppm Water	ppm	ASTM D6304	>500	220	112.8	188.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		20796	61595	31277
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>^</u> 23158	<u>▲</u> 13977
Particles >14μm		ASTM D7647	>80	<u> </u>	△ 794	△ 929
Particles >21µm		ASTM D7647	>20	△ 303	<u>109</u>	<u>^</u> 243
Particles >38μm		ASTM D7647	>4	<u> </u>	4	<u> </u>
Particles >71µm		ASTM D7647	>3	1	0	5
•						
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/20/17</u>	<u>22/17</u>	<u>△</u> 21/17



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

: KCPA014273 : 06238374 Unique Number : 11127208

Received : 16 Jul 2024 **Tested** : 17 Jul 2024 : 18 Jul 2024 - Don Baldridge Diagnosed

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

A & B CONVERTERS INC

688 MARYLAND AVE BURLINGTON, WI US 53105 Contact: STEVE

steve@abcattech.com

T: F: Contact/Location: STEVE ? - ABCBURWI