


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AS25T 5574005 (S/N 1270)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar2017	May2018 Jun2019	Jun2020 Jun2021 May2023	Jul2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018742	KCPA001959	KCP42343
Sample Date		Client Info		08 Jul 2024	17 May 2023	30 Jun 2021
Machine Age	hrs	Client Info		30894	26432	19160
Oil Age	hrs	Client Info		4457	0	4499
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	12	10	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	2	4	2
Calcium	ppm	ASTM D5185m	0	0	2	0
Phosphorus	ppm	ASTM D5185m	0	0	4	8
Zinc	ppm	ASTM D5185m	0	4	<1	0
Sulfur	ppm	ASTM D5185m	23500	23660	23071	17669
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	2
Sodium	ppm	ASTM D5185m		<1	1	0
Potassium	ppm	ASTM D5185m	>20	0	1	<1
Water	%	ASTM D6304	>0.05	0.009	0.007	0.007
ppm Water	ppm	ASTM D6304	>500	92	76.4	79.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		4271	795	660
Particles >6µm		ASTM D7647	>1300	1623	257	147
Particles >14μm		ASTM D7647	>80	<u> </u>	15	15
Particles >21µm		ASTM D7647	>20	<u></u> 54	3	4
Particles >38μm		ASTM D7647	>4	4	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/18/15	17/15/11	14/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number Unique Number : 11127222

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA018742 : 06238388

Received : 16 Jul 2024 **Tested** Diagnosed

: 17 Jul 2024

: 18 Jul 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

VILLA MACHINE ASSOCIATES

61 MCDONALD ST DEDHAM, MA US 02026 Contact: LOU VILLA

lou.villa@villamachiine.com

T:

Contact/Location: LOU VILLA - VILDED

F: