


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER ASD 40 8810751 (S/N 1566)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun2023	Jun2024		
CAMPLE INFORM	AATIONI	and the section of	Para Note and a		let a trained	history O
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017493	KCP54867	
Sample Date		Client Info		27 Jun 2024	21 Jun 2023	
Machine Age	hrs	Client Info		13605	4794	
Oil Age	hrs	Client Info		8811	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ATTENTION	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	24	1	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	58	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	2	76	
Calcium	ppm	ASTM D5185m	0	0	<1	
Phosphorus	ppm	ASTM D5185m	0	0	0	
Zinc	ppm	ASTM D5185m	0	134	2	
Sulfur	ppm	ASTM D5185m	23500	20689	23401	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		<1	20	
Potassium	ppm	ASTM D5185m	>20	0	4	
Water	%	ASTM D6304	>0.05	0.005	0.019	
ppm Water	ppm	ASTM D6304	>500	57	195.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5661	2905	
Particles >6µm		ASTM D7647	>1300	<u> </u>	1031	
Particles >14μm		ASTM D7647	>80	150	1 03	
Particles >21µm		ASTM D7647	>20	37	2 9	
Particles >38μm		ASTM D7647	>4	3	1	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/14	19/17/14	
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
Asid Number (AN)	1/011/	ACTM DODAE	4.0	0.44	0.44	

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.41

0.44



OIL ANALYSIS REPORT







Laboratory Sample No.

: KCPA017493 Lab Number : 06238398 Unique Number : 11127232

Received : 16 Jul 2024 **Tested** : 17 Jul 2024 Diagnosed

: 18 Jul 2024 - Don Baldridge

LARAMIE, WY US 82070 Contact: Service Manager

1461 COMMERCE DR

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: PLELAR [WUSCAR] 06238398 (Generated: 07/18/2024 12:38:02) Rev: 1

Contact/Location: Service Manager - PLELAR

T:

F: