


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER BSD 60T 6429384 (S/N 1239)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2021) Mar2021	Aug2022 Ju	12024	
SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA020078	KCP28601	KCP28161
Sample Date		Client Info		11 Jul 2024	29 Aug 2022	05 Mar 2021
Machine Age	hrs	Client Info		22245	12716	6995
Oil Age	hrs	Client Info		3379	2717	2571
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	2	0
Aluminum	ppm	ASTM D5185m	>10	<1	1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	9	7	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	10
Barium	ppm	ASTM D5185m	90	0	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	18	22	28
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	2	<1
Zinc	ppm	ASTM D5185m		5	19	23
Sulfur	ppm	ASTM D5185m		20944	15969	14644
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		6	7	11
Potassium	ppm	ASTM D5185m	>20	1	3	5
Water	%	ASTM D6304	>0.05	0.015	0.020	0.013
ppm Water	ppm	ASTM D6304	>500	155	208.3	138.0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		497	4424	
Particles >6µm		ASTM D7647	>1300	166	1256	
Particles >14µm		ASTM D7647	>80	20	59	
Particles >21µm		ASTM D7647	>20	7	13	
Particles >38µm		ASTM D7647	>4	1	0	
Particles >71µm		ASTM D7647		1	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/15/11	19/17/13	
FLUID DEGRADA	TION_	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number Unique Number : 11127247

: KCPA020078 : 06238413

Received **Tested** Diagnosed

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: 17 Jul 2024

: 18 Jul 2024 - Don Baldridge Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 16 Jul 2024

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Contact: J. PILGRIM jpilgrim@mmcontainer.com T:

Report Id: MMICHATN [WUSCAR] 06238413 (Generated: 07/18/2024 12:48:27) Rev: 1

Contact/Location: J. PILGRIM - MMICHATN

F:

US 37404

1435 E 14TH ST

CHATTANOOGA, TN