


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# KAESER ASD 25 7895343 (S/N 1137)

Component Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Auj	2022	Jun2023 Jul202	4	
SAMPLE INFORM	MATION		lii+/l		المراجعة والمراجعة	history.O
	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA020788	KCPA002142	KC104604
Sample Date		Client Info		09 Jul 2024	16 Jun 2023	12 Aug 2022
Machine Age	hrs	Client Info		1278	709	329
Oil Age	hrs	Client Info		500	0	0
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		3	<1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	5	4	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	0	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	1	<1
Magnesium	ppm	ASTM D5185m		4	6	7
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	506	424	281
Zinc	ppm	ASTM D5185m		130	63	9
Sulfur	ppm	ASTM D5185m		2482	3702	6249
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	1	0
Sodium	ppm	ASTM D5185m		1	2	<1
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.004	0.003	0.006
ppm Water	ppm	ASTM D6304	>500	48	26.0	66.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		941	2285	51062
Particles >6µm		ASTM D7647	>1300	223	494	<u>11904</u>
Particles >14µm		ASTM D7647	>80	20	28	<b>△</b> 925
Particles >21µm		ASTM D7647	>20	6	7	<u>^</u> 215
Particles >38µm		ASTM D7647	>4	1	0	<u>^</u> 6
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/11	18/16/12	<u>\$\rightarrow\$ 23/21/17</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	1.22	1.33	0.86



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

Lab Number Unique Number : 11127250

: KCPA020788

: 06238416

Received : 16 Jul 2024 **Tested** : 17 Jul 2024 : 18 Jul 2024 - Don Baldridge Diagnosed

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1429 TUBBS LN

CALISTOGA, CA US 94515

Contact:

T: F: