


# **OIL ANALYSIS REPORT**

# **GATHERING STATIONS/BOA GATHERING STATION [25637]** MRC-205 - BOA 4 (S/N F62004)

Compressor

**TULCO LUBSOIL LPG WS 150 (--- GAL)** 



### **DIAGNOSIS**

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO60002715	TO60002558	TO60002582
Sample Date		Client Info		02 Jul 2024	30 May 2024	08 May 2024
Machine Age	hrs	Client Info		25637	24848	24422
Oil Age	hrs	Client Info		0	0	0
Oil Changed	0	Client Info		Not Changd	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	7	2
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m		<1	0	<1
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		<1	0	<1
Aluminum	ppm	ASTM D5185m	>25	2	1	2
Lead	ppm	ASTM D5185m	>25	2	18	4
Copper	ppm	ASTM D5185m	>50	40	4	<b>4</b> 9
Tin	ppm	ASTM D5185m	>15	2	<1	3
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	33	69	50
Barium	ppm	ASTM D5185m	0	0	<1	0
Molybdenum	ppm	ASTM D5185m	0	<1	<1	2
Manganese	ppm	ASTM D5185m		1	<1	0
Magnesium	ppm	ASTM D5185m	0	11	12	8
Calcium	ppm	ASTM D5185m	0	1336	1507	1356
Phosphorus	ppm	ASTM D5185m	0	303	297	320
Zinc	ppm	ASTM D5185m	0	358	400	362
Sulfur	ppm	ASTM D5185m	0	3484	3153	2955
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	2	3
Sodium	ppm	ASTM D5185m		6	6	2
Potassium	ppm	ASTM D5185m	>20	4	4	2
Water	%	ASTM D6304	>2.26	0.117	0.069	0.081
ppm Water	ppm	ASTM D6304	>22600	1170	690	810
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u>▲</u> 58785	<b>△</b> 145957	7936
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>22425</u>	994
Particles >14μm		ASTM D7647	>320	79	48	24
Particles >21µm		ASTM D7647	>80	10	3	4
Particles >38µm		ASTM D7647	>20	1	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/17/15	<u>23/21/13</u>	<u>4</u> 24/22/13	20/17/12
FLUID DEGRADA	MOITA	method	limit/base	current	history1	history2
T LOID DEGITADA	111011			oarrone	Thotoly I	motory




## OIL ANALYSIS REPORT




Wat	er (KF	)						
70000 Sever	e	i						j
								1
60000								
40000 40000 Abro								
40000								
≥ 30000 + Abno	mal							
20000 -								•
10000								
و ا		_						-
2/21	2/21	9/21	1/22	3/22	1/23	/24	/24	
Jul	Nov2	Jec29,	Jul22/	Sep13/	eb 14	Apr1	May30/	
			-5	Š	ď.		Σ	







Water (KF)

8000











Certificate 12367

Laboratory Sample No.

: 06238456 Lab Number Unique Number : 11127290

: TO60002715

**Bottom** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 16 Jul 2024 **Tested** : 18 Jul 2024 Diagnosed

: 18 Jul 2024 - Doug Bogart Test Package : MOB 2 ( Additional Tests: KF, KV100, PrtCount, VI )

To discuss this sample report, contact Customer Service at 1-800-237-1369.  $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Contact: HERMAN GARZA herman\_garza@eogresources.com T: (432)686-3600

**EOG RESOURCES INC. - MIDLAND** 

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

5509 CHAMPIONS DRIVE

MIDLAND, TX

US 79706