


# **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



Machine Id
SL 3B
Component
Hydraulic System
Fluid
SHELL TELLUS S2 MX 46 (--- GAL)

#### DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

## Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.


## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


w/2014 Aug2016 Jan2019 Sep2020 Jan2021 0c2022 Ju2023 Mm2024						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0037242	RP0028397	RP0028395
Sample Date		Client Info		03 Jul 2024	28 Mar 2024	21 Mar 2024
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	4	0	2
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		<1	0	0
Aluminum	ppm	ASTM D5185m	>20	1	0	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>20	6	1	<1
Tin	ppm	ASTM D5185m	>20	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	3	0
Manganese	ppm	ASTM D5185m	0	1	0	0
Magnesium	ppm	ASTM D5185m	70	45	52	46
Calcium	ppm	ASTM D5185m	10	4	83	3
Phosphorus	ppm	ASTM D5185m	300	275	264	256
Zinc	ppm	ASTM D5185m	325	284	284	272
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1	<1	<1
Sodium	ppm	ASTM D5185m		4	2	2
Potassium	ppm	ASTM D5185m	>20	3	0	0
Water	%	ASTM D6304	>0.05	0.010	0.005	0.007
ppm Water	ppm	ASTM D6304	>500	105	60	71
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>5000	1322	1705	1571
Particles >6µm		ASTM D7647	>1300	186	312	357
Particles >14μm		ASTM D7647	>160	11	29	28
Particles >21µm		ASTM D7647	>40	2	8	7
Particles >38μm		ASTM D7647	>10	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	18/15/11	18/15/12	18/16/12
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.35	0.36	0.35	0.39





## **OIL ANALYSIS REPORT**




20k -	4µт 6µт 14µ	m m				A	
20k - 15k - 10k - 15k - 10k -							
10k -						1	
5k - 🕰	ormal		^		<u> </u>	1	L
0k			white Special	Acres de la constante de la co	SHOULD BE SHOWN	Jul9/23	Mar28/24









FLUID PROPER	THES	method			riistory i	HISTORY
Visc @ 40°C	cSt	ASTM D445	46.0	46.4	47.2	47.1

SAMPLE IMAGES	CANADI			$\circ$
	SAMPL	4E I	MAN	GES

**Bottom** 


Color






**GRAPHS** Ferrous Alloys

Non-ferrous Metals





0.7 (mg KOH/g) 0.7 0.5 0.2





Certificate 12367

Laboratory Sample No. Lab Number

: 06238492 Unique Number : 11127326

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : RP0037242 Received : 16 Jul 2024 **Tested** 

Test Package : IND 2

: 18 Jul 2024

Diagnosed : 18 Jul 2024 - Wes Davis

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**JOHNSON CONTROLS** 

1890 MINES RD PULASKI, TN US 38478

Contact: JEREMY ROSE jeremy.b.rose@adient.com

T: F:

Report Id: JOHPUL [WUSCAR] 06238492 (Generated: 07/18/2024 07:10:05) Rev: 1

Contact/Location: JEREMY ROSE - JOHPUL