




PROBLEM SUMMARY

Area
PRE
 Machine Id
2 EXTRUDER
 Component
Gearbox
 Fluid
PETRO CANADA ENDURATEX EP 320 (16 GAL)


Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	---	---
Water	%	ASTM D6304	>0.2	▲ 7.50	---	---
ppm Water	ppm	ASTM D6304	>2000	▲ 75000	---	---
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	---	---

Customer Id: BLURICIN
 Sample No.: WC0965387
 Lab Number: 06239136
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
PRE
 Machine Id
2 EXTRUDER
 Component
Gearbox
 Fluid
PETRO CANADA ENDURATEX EP 320 (16 GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

Wear

All component wear rates are normal.

▲ Contamination

There is a very high concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0965387	---	---
Sample Date	Client Info		12 Jul 2024	---	---
Machine Age	days	Client Info	0	---	---
Oil Age	days	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			SEVERE	---	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		72	---	---
Iron	ppm	ASTM D5185m >200	110	---	---
Chromium	ppm	ASTM D5185m >15	<1	---	---
Nickel	ppm	ASTM D5185m >15	<1	---	---
Titanium	ppm	ASTM D5185m	0	---	---
Silver	ppm	ASTM D5185m	0	---	---
Aluminum	ppm	ASTM D5185m >25	1	---	---
Lead	ppm	ASTM D5185m >100	0	---	---
Copper	ppm	ASTM D5185m >200	<1	---	---
Tin	ppm	ASTM D5185m >25	1	---	---
Vanadium	ppm	ASTM D5185m	0	---	---
Cadmium	ppm	ASTM D5185m	0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 55	4	---	---
Barium	ppm	ASTM D5185m 0	1	---	---
Molybdenum	ppm	ASTM D5185m 0	0	---	---
Manganese	ppm	ASTM D5185m 0	<1	---	---
Magnesium	ppm	ASTM D5185m 0	3	---	---
Calcium	ppm	ASTM D5185m 0	19	---	---
Phosphorus	ppm	ASTM D5185m 240	406	---	---
Zinc	ppm	ASTM D5185m 1	19	---	---
Sulfur	ppm	ASTM D5185m 13700	6650	---	---

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	9	---	---
Sodium	ppm	ASTM D5185m	4	---	---
Potassium	ppm	ASTM D5185m >20	7	---	---
Water	%	ASTM D6304 >0.2	▲ 7.50	---	---
ppm Water	ppm	ASTM D6304 >2000	▲ 75000	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	0.84	---	---



OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	● MILKY	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	325	340	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image
Bottom				no image	no image

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0965387 **Received** : 17 Jul 2024
Lab Number : 06239136 **Tested** : 19 Jul 2024
Unique Number : 11127970 **Diagnosed** : 19 Jul 2024 - Don Baldrige
Test Package : PLANT

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

BLUE BUFFALO
 4748 WEST INDUSTRIES ROAD
 RICHMOND, IN
 US 47374
 Contact: KEVIN KEITH
 kkeith@bluebuff.com
 T: (765)200-6535
 F: