


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

8811369 (S/N 2062)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Feb 2024	Jul2024		
CAMPLE INCOR	AATION		11 1-0			
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC128620	KC06107447	
Sample Date		Client Info		08 Jul 2024	27 Feb 2024	
Machine Age	hrs	Client Info		13638	10475	
Oil Age	hrs	Client Info		3200	0	
Oil Changed		Client Info		Not Changd	N/A	
Sample Status				NORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	<1	3	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	58	60	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	68	47	
Calcium	ppm	ASTM D5185m	2	2	2	
Phosphorus	ppm	ASTM D5185m	_	0	<1	
Zinc	ppm	ASTM D5185m		0	0	
CONTAMINANTS			limit/bass			hiotory?
		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	1	
Sodium	ppm	ASTM D5185m		17	17	
Potassium	ppm	ASTM D5185m	>20	4	9	
Water	%	ASTM D6304	>0.05	0.031	0.008	
ppm Water	ppm	ASTM D6304	>500	311	89	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1452	6426	
Particles >6µm		ASTM D7647	>1300	551	2290	
Particles >14μm		ASTM D7647	>80	38	153	
Particles >21µm		ASTM D7647	>20	5	35	
Particles >38μm		ASTM D7647	>4	0	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	20/18/14	
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.38

0.33



OIL ANALYSIS REPORT







Certificate 12367

Sample No. : KC128620 Lab Number : 06239155 Unique Number : 11127989 Test Package : IND 2

Received : 17 Jul 2024 **Tested** Diagnosed

: 18 Jul 2024 : 19 Jul 2024 - Don Baldridge 4707 DETROIT RD CLEVELAND, OH US 44102

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - LAICLE

T:

F: