

## **OIL ANALYSIS REPORT**

Area PG 46 [288995] INGERSOLL RAND NV3986U11202 - TWINPLEX STAMPING Component

Compressor

## DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

## Wear

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0001344		
Sample Date		Client Info		10 Jul 2024		
Machine Age	hrs	Client Info		41385		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	3		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	3		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	3		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		298		
Zinc	ppm	ASTM D5185m		48		
Sulfur	ppm	ASTM D5185m		912		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42		



# **OIL ANALYSIS REPORT**



						history1	history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
5	Sand/Dirt	scalar	*Visual	NONE	NONE			
Jul10/24	Appearance	scalar	*Visual	NORML	NORML			
	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water Free Water	scalar	*Visual	>0.1	NEG			
1		scalar	*Visual		NEG			
	FLUID PROPERT	TIES	method	limit/base		history1	history2	
1	Visc @ 40°C	cSt	ASTM D445		48.9			
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
Jult0/24	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Meta	ls		Jul10/24				
	Viscosity @ 40°C			0 4cid Number (10) 0 Mumber (1	20			
Laboratory Sample No. Lab Number Unique Number tificate L2367 Test Package	: UFD0001344 : <mark>06239265</mark> : 11128099	Rece Teste	Madison Ave., Cary, NC 27513 Received : 17 Jul 2024 Tested : 18 Jul 2024 Diagnosed : 18 Jul 2024 - Wes Davis			FLUID-AIRE DYNAMIC 225 SPRING LAKE DI ITASCA, I US 6014 Contact: ED DIENEI		

Contact/Location: ED DIENER - UCFLUSCH