




# PROBLEM SUMMARY

## Sample Rating Trend




WATER



Machine Id  
**FS CUTRIS HE11F22022 - WEST FRASER INC**  
 Component  
**Compressor**  
 Fluid  
**PG-32 (--- GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you check for the source of water entry. We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Water	%	ASTM D6304	>0.1	▲ 2.54	---	---
ppm Water	ppm	ASTM D6304	>1000	▲ 25400	---	---
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	NEG

Customer Id: AIRGREWC  
 Sample No.: WC0947069  
 Lab Number: 06239280  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Sean Felton +1 919-379-4092  
[sfelton@wearcheckusa.com](mailto:sfelton@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Change Filter	---	---	?	We recommend that you drain the oil and perform a filter service on this component if not already done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

## HISTORICAL DIAGNOSIS

### DEGRADATION



#### 05 Mar 2024 Diag: Don Baldrige

We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is above the recommended limit. The oil is no longer serviceable.

view report



### DEGRADATION



#### 09 Nov 2023 Diag: Jonathan Hester

We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is above the recommended limit. The oil viscosity is higher than normal. The oil is no longer serviceable.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id  
**FS CUTRIS HE11F22022 - WEST FRASER INC**  
 Component  
**Compressor**  
 Fluid  
**PG-32 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you check for the source of water entry. We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high concentration of water present in the oil.

### Fluid Condition

The oil is no longer serviceable due to the presence of contaminants.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0947069</b>	WC0897656	WC0811763
Sample Date	Client Info		<b>15 Jul 2024</b>	05 Mar 2024	09 Nov 2023
Machine Age	hrs	Client Info	<b>12712</b>	10660	9522
Oil Age	hrs	Client Info	<b>4000</b>	4000	2000
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	SEVERE	SEVERE

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>1</b>	0	0
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>3</b>	0	0
Lead	ppm	ASTM D5185m >25	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	<1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>8</b>	0	0
Barium	ppm	ASTM D5185m	<b>311</b>	386	268
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>2</b>	0	0
Calcium	ppm	ASTM D5185m	<b>0</b>	2	0
Phosphorus	ppm	ASTM D5185m	<b>19</b>	21	28
Zinc	ppm	ASTM D5185m	<b>4</b>	0	0
Sulfur	ppm	ASTM D5185m	<b>510</b>	537	458




## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>4</b>	2	2
Sodium	ppm	ASTM D5185m	<b>40</b>	46	60
Potassium	ppm	ASTM D5185m >20	<b>5</b>	3	3
Water	%	ASTM D6304 >0.1	<b>▲ 2.54</b>	---	---
ppm Water	ppm	ASTM D6304 >1000	<b>▲ 25400</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.46</b>	<b>▲ 1.12</b>	<b>▲ 2.421</b>

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.0	46.4	▲ 49.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0947069      **Received** : 17 Jul 2024  
**Lab Number** : 06239280      **Tested** : 18 Jul 2024  
**Unique Number** : 11128114      **Diagnosed** : 19 Jul 2024 - Sean Felton  
**Test Package** : IND 2 ( Additional Tests: KF )

**FS-COMPRESSION CO, LLC**  
 203 AERO COURT  
 GREENSBORO, NC  
 US 27409

Contact: Dallas Burcham  
 dallas.burcham@fs-compression.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (336)605-9622

F: (336)605-9844