# OIL ANALYSIS REPORT

Sample Rating Trend




NORMAL

Area
## ALL ADVANTAGE [154239]
Machine Id
## CBV380130 - TRI PART SCREW
Component
**Compressor**

## DIAGNOSIS

**Recommendation**
Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

**Wear**
All component wear rates are normal.

**Contamination**
There is no indication of any contamination in the oil.

**Fluid Condition**
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Sample Number | | Client Info | | **UCH06239289** | UCH05865779 | UCH05783906 |
| Sample Date | | Client Info | | **11 Jul 2024** | 31 May 2023 | 27 Feb 2023 |
| Machine Age | hrs | Client Info | | **51270** | 48146 | 46562 |
| Oil Age | hrs | Client Info | | **3124** | 6555 | 9971 |
| Oil Changed | | Client Info | | **Not Changd** | Changed | Not Changd |
| Sample Status | | | | **NORMAL** | NORMAL | ABNORMAL |

| CONTAMINATION | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Water | | WC Method | >0.1 | **NEG** | NEG | NEG |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Iron | ppm | ASTM D5185m | >50 | **4** | 0 | <1 |
| Chromium | ppm | ASTM D5185m | >10 | **<1** | 0 | 0 |
| Nickel | ppm | ASTM D5185m | | **<1** | 0 | 0 |
| Titanium | ppm | ASTM D5185m | | **<1** | 0 | 0 |
| Silver | ppm | ASTM D5185m | | **0** | 0 | <1 |
| Aluminum | ppm | ASTM D5185m | >25 | **3** | <1 | <1 |
| Lead | ppm | ASTM D5185m | >25 | **<1** | 0 | 1 |
| Copper | ppm | ASTM D5185m | >50 | **2** | 4 | 9 |
| Tin | ppm | ASTM D5185m | >15 | **<1** | 0 | <1 |
| Vanadium | ppm | ASTM D5185m | | **0** | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | **<1** | 0 | 0 |

| ADDITIVES | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Boron | ppm | ASTM D5185m | | **0** | 0 | 0 |
| Barium | ppm | ASTM D5185m | | **<1** | 0 | 1 |
| Molybdenum | ppm | ASTM D5185m | | **<1** | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | **<1** | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | | **<1** | 0 | <1 |
| Calcium | ppm | ASTM D5185m | | **0** | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | | **239** | 188 | 235 |
| Zinc | ppm | ASTM D5185m | | **100** | 46 | 70 |
| Sulfur | ppm | ASTM D5185m | | **832** | 1292 | 1297 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Silicon | ppm | ASTM D5185m | >25 | **2** | 1 | 3 |
| Sodium | ppm | ASTM D5185m | | **0** | <1 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | **1** | 0 | <1 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | **0.27** | 0.28 | 0.32 |

# OIL ANALYSIS REPORT







| VISUAL | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| White Metal | scalar | *Visual | NONE | **NONE** | NONE | VLITE |
| Yellow Metal | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Silt | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Debris | scalar | *Visual | NONE | **NONE** | MODER | LIGHT |
| Sand/Dirt | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Appearance | scalar | *Visual | NORML | **NORML** | NORML | NORML |
| Odor | scalar | *Visual | NORML | **NORML** | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | **NEG** | NEG | ▲ 0.2% |
| Free Water | scalar | *Visual | | **NEG** | NEG | ▲ 1.0 |

| FLUID PROPERTIES | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Visc @ 40°C | cSt | ASTM D445 | | **43.4** | 43.6 | 43.8 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|
| Color | | |  |  |  |
| Bottom | | |  |  |  |

## GRAPHS













Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513
**Sample No.** : UCH06239289
**Lab Number** : 06239289
**Unique Number** : 11128123
**Test Package** : IND 2

**Received** : 17 Jul 2024
**Tested** : 18 Jul 2024
**Diagnosed** : 18 Jul 2024 - Wes Davis

*To discuss this sample report, contact Customer Service at 1-800-237-1369.*
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
*Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)*

**A-L-L EQUIPMENT INC**
204 38TH ST
MOLINE, IL
US 61265
Contact: JOE DYKEMA
joe@a-l-lequipment.com
T: (309)762-8096
F: (309)762-9950