




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
TORO 30881/4500-D 115626 (S/N 13049)
 Component
Diesel Engine
 Fluid
TRC PRO-SPEC IV XP SYN BLEND SAE 10W30 (6 QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		TR06239332	TR06159330	TR05940335
Sample Date	Client Info		16 Jul 2024	23 Apr 2024	29 Aug 2023
Machine Age	hrs	Client Info	2903	2669	2475
Oil Age	hrs	Client Info	1523	1289	1095
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			NORMAL	NORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >80	37	23	▲ 97
Chromium	ppm	ASTM D5185m >6	1	1	3
Nickel	ppm	ASTM D5185m >2	1	<1	2
Titanium	ppm	ASTM D5185m >2	<1	<1	<1
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >20	3	4	8
Lead	ppm	ASTM D5185m >95	1	1	5
Copper	ppm	ASTM D5185m >85	4	3	21
Tin	ppm	ASTM D5185m >9	<1	<1	<1
Vanadium	ppm	ASTM D5185m	0	<1	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	<1	0	0
Molybdenum	ppm	ASTM D5185m	2	2	3
Manganese	ppm	ASTM D5185m	<1	<1	1
Magnesium	ppm	ASTM D5185m	17	17	23
Calcium	ppm	ASTM D5185m	4656	4417	6304
Phosphorus	ppm	ASTM D5185m	940	1077	1337
Zinc	ppm	ASTM D5185m	1208	1207	1645
Sulfur	ppm	ASTM D5185m	4251	6223	5912

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	11	11	12
Sodium	ppm	ASTM D5185m	3	6	11
Potassium	ppm	ASTM D5185m >20	4	4	4

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	1.9	0.9	3.1
Nitration	Abs/cm	*ASTM D7624 >20	14.5	10.6	20.2
Sulfation	Abs/.1mm	*ASTM D7415 >30	27.8	21.0	36.9


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	19.6	13.2	27.7
Base Number (BN)	mg KOH/g	ASTM D2896	12.35	14.66	10.98




OIL ANALYSIS REPORT


FT-IR (Direct Trend)



Base Number



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.0	12.3	15.1

GRAPHS


Iron (ppm)




Lead (ppm)




Aluminum (ppm)




Chromium (ppm)




Copper (ppm)




Silicon (ppm)



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : TR06239332
 Lab Number : 06239332
 Unique Number : 11128166
 Test Package : MOB 2

Received : 17 Jul 2024
 Tested : 18 Jul 2024
 Diagnosed : 18 Jul 2024 - Wes Davis

OVERLAND PARK GC CCD
 1801 S HURON ST
 DENVER, CO
 US 80223
 Contact: JAMES WEST

To discuss this sample report, contact Customer Service at 1-800-827-0711.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: