


# **OIL ANALYSIS REPORT**



Machine Id

## Control oil Component Turbine

Turbine Fluid {not provided} (--- GAL)

#### DIAGNOSIS

#### A Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0839387	WC0814545	WC0814539
Sample Date		Client Info		10 Jul 2024	05 Mar 2024	24 Oct 2023
Machine Age	hrs	Client Info		26286	26286	60
Oil Age	hrs	Client Info		26286	26286	60
Oil Changed		Client Info		N/A	Filtered	Filtered
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.03	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	<1	0	0
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m		0	0	0
Copper	ppm	ASTM D5185m	>5	0	0	0
Tin	ppm	ASTM D5185m	>5	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		1	0	0
Calcium	ppm	ASTM D5185m		1	0	2
Phosphorus	ppm	ASTM D5185m		1056	1001	1068
Zinc	ppm	ASTM D5185m		20	18	9
Sulfur	ppm	ASTM D5185m		236	178	197
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	4	3	4
Sodium	ppm	ASTM D5185m		<1	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	<b>6778</b>	16780	021
Particles >6µm		ASTM D7647	>640	<u> </u>	<mark>▲</mark> 3083	<u> </u>
Particles >14µm		ASTM D7647	>80	<mark>/</mark> 212	<b>1</b> 58	148
Particles >21µm		ASTM D7647	>20	<u> </u>	<u> </u>	<b>4</b> 9
Particles >38µm		ASTM D7647	>4	<mark> </mark> 8	2	<b>5</b>
Particles >71µm		ASTM D7647	>3	1	0	1
Oil Cleanliness		ISO 4406 (c)	>18/16/13	<b>A</b> 20/18/15	<b>A</b> 21/19/14	9/17/14
FLUID DEGRADA	TION	method	limit/base	ourropt	history1	history2
I LOID DEGINADA		method	in the babe	current	HIStory	Thotory 2




# **OIL ANALYSIS REPORT**







			11 11 11			
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	🔺 MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
						1120
FLUID PROPERT	IES	method	limit/base	current		
FLUID PROPERT Visc @ 40°C	IES cSt	method ASTM D445	limit/base	current 45.4	history1 44.9	history2 44.6
	cSt		limit/base limit/base		history1	history2
Visc @ 40°C	cSt	ASTM D445		45.4	history1 44.9	history2 44.6



Laboratory Sample No. Lab Number : 06239562 Tested : 18 Jul 2024 CARNESVILLE, GA Unique Number : 11128396 Diagnosed : 19 Jul 2024 - Don Baldridge US 30521 Test Package : IND 2 Contact: JOHNNY STONE Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. johnny.stone@veolia.com \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: 

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: JOHNNY STONE Page 2 of 2

F: