


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 9120560

Component Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Dec2023	Jul2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018079	KC06049569	
Sample Date		Client Info		13 Jul 2024	22 Dec 2023	
Machine Age	hrs	Client Info		2907	2125	
Oil Age	hrs	Client Info		782	0	
Oil Changed	1110	Client Info		Changed	N/A	
Sample Status		Onoric iriio		ABNORMAL	SEVERE	
-						
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	4	1 06	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	3	<u>12</u>	
Lead	ppm	ASTM D5185m	>10	0	1	
Copper	ppm	ASTM D5185m	>50	4	3	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	<1	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	1	
Magnesium	ppm	ASTM D5185m	90	42	<1	
Calcium	ppm	ASTM D5185m	2	0	2	
Phosphorus	ppm	ASTM D5185m		8	52	
Zinc	ppm	ASTM D5185m		57	12	
Sulfur	ppm	ASTM D5185m		18264	418	
CONTAMINANTS	i	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		15	2	
Potassium	ppm	ASTM D5185m	>20	2	<1	
Water	%	ASTM D6304	>0.05	0.023	△ 0.104	
ppm Water	ppm	ASTM D6304	>500	231	<u></u> 1040	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5533		
Particles >6µm		ASTM D7647	>1300	<u> 2442</u>		
Particles >14µm		ASTM D7647	>80	4 335		
Particles >21µm		ASTM D7647	>20	<u></u> 91		
Particles >38µm		ASTM D7647	>4	3		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/16		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A : I N I (ANI)	1/011/	AOTH DOOLS	0.4	0.27	0.11	

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.14

0.37



OIL ANALYSIS REPORT





Certificate 12367

Sample No.

Laboratory Lab Number

: KCPA018079 : 06239576 Unique Number : 11128410

Received

: 17 Jul 2024 **Tested** Diagnosed

: 18 Jul 2024 : 19 Jul 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

340 DUNAVANT DR

ROCKFORD, TN US 37853 Contact: GRAY W.

grayw@cintas.com

T:

F: Contact/Location: GRAY W. - CINROCTN