


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# QUINCY QUINCY (S/N UTY203660)

Air Compressor

**QUINCY QUINSYN F (--- GAL)** 

		IS	

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb2021	Aug2021 Feb2022	Oct2022 May2023 Aug2023	Jul2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM37059	USPM36624	USPM29540
Sample Date		Client Info		16 Jul 2024	02 Apr 2024	31 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	1	<1
Chromium	ppm	ASTM D5185m	>4	0	<1	0
Nickel	ppm	ASTM D5185m	>4	0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>20	0	<1	0
Copper	ppm	ASTM D5185m	>40	0	<1	0
Tin	ppm	ASTM D5185m	>5	0	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		1	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	168
Zinc	ppm	ASTM D5185m		2	0	0
Sulfur	ppm	ASTM D5185m		<1	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		<1	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.6	0.030	0.071	0.004
ppm Water	ppm	ASTM D6304	>6000	304	710	43.2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	3620		<u></u>
Particles >6µm		ASTM D7647	>2500	1273		<u>▲</u> 14847
Particles >14μm		ASTM D7647	>320	124		<u></u> 511
Particles >21µm		ASTM D7647	>80	27		<b>△</b> 95
Particles >38µm		ASTM D7647	>20	1		3
Particles >71µm		ASTM D7647	>4	0		0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/14		<b>△</b> 23/21/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	.10	0.33	0.30	0.27



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No. Lab Number

: USPM37059 : 06239594 Unique Number : 11128428 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 17 Jul 2024

**Tested** : 18 Jul 2024 Diagnosed : 18 Jul 2024 - Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: DANNY SAUL - TYSGRE

TYSON FOODS-GREEN FOREST-PRE

US 72638

601 TYSON DRIVE

GREEN FOREST, AR

Contact: DANNY SAUL

dale.west@tyson.com

T: (870)438-5211

F: (870)438-7194