


## **OIL ANALYSIS REPORT**

### Sample Rating Trend



NORMAL



Machine Id

# **GEA PAR FRY LS-3**

Component Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		pr2018 Mar20	019 Jan 2020 Dec 2020	May2021 Feb2022 Jan2023	Dec2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0014998	USP0008036	USP0004219
Sample Date		Client Info		16 Jul 2024	02 Apr 2024	14 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<1	2	0
Chromium	ppm	ASTM D5185m	>2	0	<1	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	<1	0
Copper	ppm	ASTM D5185m	>8	0	<1	0
Tin	ppm	ASTM D5185m	>4	0	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		1	<1	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	1
Zinc	ppm	ASTM D5185m		1	0	0
Sulfur	ppm	ASTM D5185m	50	1	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	3	4	2
Sodium	ppm	ASTM D5185m		<1	2	0
Potassium	ppm	ASTM D5185m	>20	0	<1	2
Water	%	ASTM D6304	>0.01	0.002	0.006	0.006
ppm Water	ppm	ASTM D6304	>100	24	68	67
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		248	1784	214
Particles >6µm		ASTM D7647	>2500	80	536	55
Particles >14µm		ASTM D7647	>320	10	54	4
Particles >21µm		ASTM D7647	>80	4	16	1
Particles >38μm		ASTM D7647	>20	1	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	15/13/10	18/16/13	15/13/9
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.014	0.014





## **OIL ANALYSIS REPORT**



Par 10k <sub>T</sub> :	ticle T	rend					
≘ 8k-		m m			-1		
E Sk + Sk		um			٨		
ted to 4k	A				/\_		
g 2k -	1	$\wedge$	1	N	1	1	7.
0k	\ <u>\</u>	-	Sanda Sanda	<u>v_</u>	$\vec{\gamma}$	Name of the last	لايد
Apr16/18	Mar19/1	Jan27/2	Jec13/2	May10/2	Feb16/22	Jan25/2	Dec14/23







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIES	method	limit/base	current	history1	history2

I LOID I HOI LITT	ILO					
Visc @ 40°C	cSt	ASTM D445	65.6	64.3	64.7	64.3

|--|



**GRAPHS** 

Color

**Bottom** 

Ferrous Alloys Particle Count 491 520 122,880 30,720 7,680 1,920 Non-ferrous Metals 480 120 Jec14/23 Viscosity @ 40°C Acid Number 20.02 20.02 10.00 10.01 0.01 0.00 G Dec14/23





Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: USP0014998 Lab Number : 06239603 Unique Number : 11128437

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 17 Jul 2024

**Tested** : 18 Jul 2024 Diagnosed : 18 Jul 2024 - Doug Bogart

TYSON FOODS-GREEN FOREST-USP GREEN FOREST, AR US

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: