

OIL ANALYSIS REPORT

NORMAL

Machine Id B-4 (S/N XD0122) Component Compressor Fluid USPI ALT-68 SC (220 LTR)

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0014965	USP0007345	USP0005664
Sample Date		Client Info		17 Jul 2024	09 Feb 2024	24 Jan 2024
Machine Age	hrs	Client Info		0	23980	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	4	3	2
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	1	0
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	0	<1	0
Tin	ppm	ASTM D5185m	>15	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	<1	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	<1
Sodium	ppm	ASTM D5185m		<1	<1	1
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.1	0.004	0.008	0.005
ppm Water	ppm	ASTM D6304	>1000	48	83	51
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	4928		14169
Particles >6µm		ASTM D7647	>2500	1030		2489
Particles >14µm		ASTM D7647	>320	32		72
Particles >21µm		ASTM D7647	>80	4		12
Particles >38µm		ASTM D7647	>20	0		0
Particles >71µm		ASTM D7647	>4	0		0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/12		21/18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.014	0.013	0.014


Contact/Location: SERVICE MANAGER ? - TRISAIUSP





OIL ANALYSIS REPORT














Bottom



: 19 Jul 2024

: 19 Jul 2024 - Doug Bogart

US Contact: SERVICE MANAGER

- To discuss this sample report, contact Customer Service at 1-800-237-1369.
- * Denotes test methods that are outside of the ISO 17025 scope of accreditation.

: 06240409

Lab Number

Unique Number : 11129243

Test Package : IND 2

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Tested

Diagnosed

Report Id: TRISAIUSP [WUSCAR] 06240409 (Generated: 07/21/2024 13:14:20) Rev: 1

Certificate 12367

Contact/Location: SERVICE MANAGER ? - TRISAIUSP

T:

F: